

NOTICE — WHEN GOVERNMENT DRAWINGS, SPECIFICATIONS, OR OTHER DATE
ARE UNED POR ANY PURPOSE OTHER PART IN CONSECUTION WITH 5 SPECIFICATIONS, OR OTHER DATE
AND UNE FACT PROPERTY PROCLEMENT OF CONTINUE TO ANY OPERATED STATES OF PRESENCE OF PROPERTY.

SYM DESCRIPTION DATE APPROVAL

BOT TO BN STEARAGED BY INFLICATION OR OTHER PRINCE OF PROPERTY.

INFLICATION OR OTHER PRINCE OF PROPERTY OF THE PART OF THE

4. TEST REQUIREMENTS:

INSPECTION AND/OR TEST

- A. TEST EQUIPMENT: CORES ARE TO BE TESTED IN AN EQUIPMENT WHICH PERMITS APPLICATION OF A "SET" PULSE OF SUFFICIENT AMPLITUDE AND DURATION TO SATURATE THE CORE UNDER TEST, FOLLOWED BY A LINEAR (APPROX) RAMP WHOSE SLOPE MAY BE MEASURED.
- B. CALIBRATION OF TEST EQUIPMENT: STANDARD CORES FURNISHED BY MIT ARE TO FORM THE BASIS OF THIS SPECIFICATION AND ARE TO BE USED FOR THE PURPOSE OF CALIBRATING THE TEST EQUIPMENT.
- C. CALIBRATION PROCEDURE: EQUIPMENT SHALL BE CONNECTED TO A WELL-REGULATED LINE SUPPLY AND ALLOWED TO STABILIZE FOR ONE HOUR BEFORE MEASUREMENTS ARE MADE.
 - 1) CALIBRATE SWEEP OF TEKTRONIX 530-340 SERIES OSCILLOSCOPE WITH TEKTRONIX TIME-MARK GENERATOR OR EQUIVALENT.
 - 2) USING TYPE D HIGH-GAIN DIFFERENCE AMPLIFTER PLUG-IN, CALIBRATE VERTICAL AMPLIFIER WITH A CALIBRATOR WHICH PERMITS THE APPLICATION OF A KNOWN (±1%) VOLTAGE TO THE VERTICAL AMPLIFIER. THE INTERNAL CALIBRATOR OF THE OSCILLOSCOPE MAY BE USED PROVIDING ITS ACCURACY HAS BEEN VERIFIED.
 - 3) ADJUST THE AMPLITUDE AND DURATION OF THE SET PULSE SO THAT THEY ARE RESPECTIVELY AT LEAST 1/2 AMPERE AND 10 usec.
 - 4) ADJUST THE SLOPE OF THE RAMP SO THAT IT INITIALLY APPROXIMATES 200 ma/uSEC. USING ONE OF THE MIT-FURNISHED STANDARD CORES, ADJUST RAMP SLOPE SO THAT MEASUREMENTS OF TIME TO PEAK, SWITCHING TIME, AND AMPLITUDE CORRESPOND TO THE DATA FURNISHED WITH THE CORES FOR THIS PARTICULAR RAMP SLOPE.
 - 5) MEASURE "1" SWITCHING WAVE FORM.
 - 6) READJUST RAMP SLOPE SO THAT IT APPROXIMATES 400 ma/uSEC. USING THE MIT-STANDARD CORE, ADJUST RAMP SLOPE SO THAT THE MEASUREMENTS OF SWITCHING TIME, TIME TO PEAK, AND AMPLITUDE CORRESPOND TO THE DATA FURNISHED WITH THE CORE FOR THIS PARTICULAR RAMP SLOPE.
 - 7) MEASURE "1" SWITCHING WAVE FORM V2.
 - 8) READJUST RAMP SLOPE SO THAT IT APPROXIMATES 1000 ma/uSEC. DISCONNECT SET PULSE. USING MIT-STANDARD CORE, ADJUST RAMP SLOPE SO THAT THE MEASUREMENTS OF PEAK "ZERO" OUTPUL VOLTAGE IS OBTAINED. USE INTEGRATING CIRCUIT, SHOWN IN FIGURE 1, WHEN PERFORMING THIS MEASUREMENT.
 - 9) MEASURE "ZERO" OUTPUT VO ON CORES, USING INTEGRATION CIRCUIT.
 - 10) REPEAT CALIBRATION PROCEDURE AFTER TESTING EACH 100 CORES OR AFTER 8 OPERATION HOURS, WHICHEVER IS SOONER.

D. DEFINITIONS:

1) TIME TO PEAK SHALL BE MEASURED FROM THE START OF THE RAMP TO THE PEAK OF THE OUTPUT VOLTAGE WAVEFORM. THE START OF THE RAMP MAY BE FOUND BY EXTENDING THE RAMP BACK UNTIL IT CROSSES THE "ZERO CURRENT " AXIS.




FIGURE 2. INTEGRATING CIRCUIT

THE VOLTAGE INDUCED BY THE TESTING JIG MUST BE TAKEN INTO ACCOUNT WHEN MEASURING $^{V}_{O}$. A TYPICAL CASE IS SHOWN IN FIGURE 3. PEAK $^{V}_{O}$ IS DEFINED AS THE MAXIMUM OF $^{V}_{O}$ ZERO" $^{-V}_{O}$ JIG.





FIGURE 3

TYPICAL OUTPUT VOLTAGES, AFTER INTEGRATION, DUE TO JIG INDUCTANCE AND RESISTANCE; COMBINED JIG AND "ZERO" OUTPUTS: CURRENT SLOPE = 1000 mA/uSEC.

G THIS SHEET ADDED



PHOTOGRAPHIC SCALE ONLY

