

make administrative revisions to reflect generic position titles in TS 6.0; correct page numbers and titles in the Table of Contents; and to delete the General Table of Contents. Bases pages were also revised to reflect the fuel specification revision, as well as to make administrative changes to provide clarity and correct a misspelling.

*Date of Issuance:* February 27, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 60 days.

*Amendment No.:* 214.

*Facility Operating License No. DPR-28:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 21, 2003 (68 FR 2802).

The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated February 27, 2003.

*No significant hazards consideration comments received:* No.

*Exelon Generation Company, LLC, Docket Nos. 50-373 and 50-374, LaSalle County Station, Units 1 and 2, LaSalle County, Illinois*

*Date of application for amendments:* September 27, 2002.

*Brief description of amendments:* The amendments change Appendix B, "Environmental Protection Plan," of the licensee by removing a parenthetical reference to a superseded section of 10 CFR part 51.

*Date of issuance:* February 20, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 157/143

*Facility Operating License Nos. NPF-11 and NPF-18:* The amendments revised the Environmental Protection Plan.

*Date of initial notice in Federal Register:* October 29, 2002 (67 FR 66009).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 20, 2003.

*No significant hazards consideration comments received:* No.

*FirstEnergy Nuclear Operating Company, et al., Docket Nos. 50-334 and 50-412, Beaver Valley Power Station, Unit Nos. 1 and 2, Beaver County, Pennsylvania*

*Date of application for amendments:* August 7, 2002.

*Brief description of amendments:* The amendments: (1) Revised the surveillance frequency for air or smoke flow testing of containment spray

nozzles, as specified in surveillance requirements (SRs) 4.6.2.1.d and 4.6.2.2.f, from, "once per 10 years," to, "following maintenance which results in the potential for nozzle blockage as determined by engineering evaluation;" (2) allowed the use of a visual examination in lieu of an air or smoke flow test; (3) relocated the SR 4.6.2.2.e.3 criteria for the river/service water flow rate through the recirculation spray system heat exchangers to the Updated Final Safety Analysis Report; and (4) made minor clarifying changes to the text in TS 3.3.1.1.

*Date of issuance:* February 24, 2003.

*Effective date:* As of date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 252 and 132.

*Facility Operating License Nos. DPR-66 and NPF-73:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 15, 2002 (67 FR 63694).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 24, 2003.

*No significant hazards consideration comments received:* No.

*FirstEnergy Nuclear Operating Company, et al., Docket Nos. 50-334 and 50-412, Beaver Valley Power Station, Unit Nos. 1 and 2, Beaver County, Pennsylvania*

*Date of application for amendments:* March 14, 2002.

*Brief description of amendments:* The amendments revised the Technical Specifications (TSs) by extending the allowed outage time (AOT), or completion time, associated with an inoperable emergency core cooling system (ECCS) accumulator. In addition to the AOT extension, other changes were incorporated to make the ECCS TSs consistent with NUREG-1431, "Standard Technical Specifications—Westinghouse Plants." Format and editorial changes were included as necessary to facilitate the revision of the TS text to conform to the current TS page format.

*Date of issuance:* February 25, 2003.

*Effective date:* As of date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 253 and 133.

*Facility Operating License Nos. DPR-66 and NPF-73:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 30, 2002 (67 FR 21289).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 25, 2003.

*No significant hazards consideration comments received:* No.

*FirstEnergy Nuclear Operating Company, et al., Docket Nos. 50-334 and 50-412, Beaver Valley Power Station, Unit Nos. 1 and 2, Beaver County, Pennsylvania*

*Date of application for amendments:* October 31, 2002, as supplemented by letters dated December 2, 2002, and January 24, 2003.

*Brief description of amendments:* The amendments revised the Technical Specifications to allow extending the Type A containment integrated leak rate test interval from 10 years to 15 years on a one-time basis.

*Date of issuance:* March 5, 2003.

*Effective date:* As of date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 254 and 134.

*Facility Operating License Nos. DPR-66 and NPF-73:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 10, 2002 (67 FR 75877).

The December 2, 2002, and January 24, 2003, supplemental letters did not change the initial no significant hazards consideration determination or expand the amendment beyond the scope of the initial notice.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 5, 2003.

*No significant hazards consideration comments received:* No.

*FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit 1, Lake County, Ohio*

*Date of application for amendment:* December 9, 2002.

*Brief description of amendment:* Pursuant to 10 CFR 50.67, this amendment approves the use of Alternative Source Term radiological calculations to update the design bases analysis for the Fuel Handling Accident as described in the Updated Safety Analysis Report. Regulatory Guide 1.183, "Alternative Radiological Source Terms for Evaluating Design-Basis Accidents at Nuclear Power Reactors," was used in the application.

*Date of issuance:* March 4, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 90 days.

*Amendment No.:* 122.

*Facility Operating License No. NPF-58:* This amendment revised the Updated Safety Analysis Report.

*Date of initial notice in Federal Register:* January 7, 2003 (68 FR 804).