

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 4, 2003.  
*No significant hazards consideration comments received:* No.

*Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant, Units 3 and 4, Miami-Dade County, Florida*

*Date of application for amendments:* August 16, 2002.

*Brief description of amendments:* The proposed amendments modified Technical Specification (TS) Surveillance Requirement Section 4.0.3 to extend the delay time for completion of a missed surveillance to 24 hours or up to the surveillance frequency, whichever is greater. Additionally the proposed change would add a TS Bases Control Program.

*Date of issuance:* March 3, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment Nos:* 222 and 217.

*Facility Operating License Nos. DPR-31 and DPR-41:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 24, 2002 (67 FR 78521).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 3, 2003.

*No significant hazards consideration comments received:* No.

*Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant, Units 3 and 4, Miami-Dade County, Florida*

*Date of application for amendments:* October 21, 2002, as supplemented by letters dated February 11, 2003, and March 3, 2003.

*Brief description of amendments:* The amendments will reduce the minimum time required for reactor subcriticality prior to removing irradiated fuel from the reactor vessel from 100 hours to 72 hours, as specified in Technical Specification 3/4.9.3 "Refueling Operations, Decay Time."

*Date of issuance:* March 4, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment Nos:* 223 and 218.

*Facility Operating License Nos. DPR-31 and DPR-41:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 12, 2002 (67 FR 68738).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 4, 2003.

*No significant hazards consideration comments received:* No.

*Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Units 1 and 2, Berrien County, Michigan*

*Date of application for amendments:* April 11, 2002, as supplemented November 11, 2002.

*Brief description of amendments:* The amendments would revise the Surveillance Requirements for containment leakage rate testing in Technical Specification 4.6.1.2 to allow a one-time extension of the interval between integrated leakage rate tests from 10 to 15 years.

*Date of issuance:* February 25, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days.

*Amendment Nos.:* 274 and 254.

*Facility Operating License Nos. DPR-58 and DPR-74:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 14, 2002 (67 FR 34488).

The supplemental letter contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 25, 2003.

*No significant hazards consideration comments received:* No.

*Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska*

*Date of amendment request:* February 28, 2001, as supplemented by letters dated February 26, September 13 and 27, and November 25, 2002 (2).

*Brief description of amendment:* The amendment consists of changes to the design-basis accidents dose assessment methodology and Operating License Condition 2.C.(6).

*Date of issuance:* February 21, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment No.:* 196.

*Facility Operating License No. DPR-46:* Amendment revised the final safety analysis report and Operating License Condition 2.C.(6).

*Date of initial notice in Federal Register:* September 19, 2001 (66 FR 48289).

The supplemental letters provided clarifying information that was within the scope of the original **Federal**

**Register** notice (66 FR 48289) and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 21, 2003.

*No significant hazards consideration comments received:* No.

*Nine Mile Point Nuclear Station, LLC, Docket No. 50-410, Nine Mile Point Nuclear Station, Unit 2, Oswego County, New York*

*Date of application for amendment:* February 3, 2003.

*Brief description of amendment:* The amendment changed Technical Specifications Surveillance Requirement 3.6.1.7.2 for suppression chamber-to-drywell vacuum breaker 2ISC\*RV36B to allow an exception to the periodic functional testing requirements for the remainder of Cycle 9.

*Date of issuance:* February 21, 2003.

*Effective date:* As of the date of issuance to be implemented within 7 days.

*Amendment No.:* 108.

*Facility Operating License No. NPF-69:* Amendment revises the Technical Specifications. Public comments requested as to proposed no significant hazards consideration: Yes. The Nuclear Regulatory Commission published a public notice of the proposed amendment, issued a proposed finding of no significant hazards consideration and requested that any comments on the proposed no significant hazards consideration be provided to the staff by the close of business on February 20, 2003. The notice was published in the Syracuse, NY, *The Post-Standard*, on February 11, 2003.

*No significant hazards consideration comments received:* No.

The Commission's related evaluation of the amendment, finding of exigent circumstances, consultation with the State of New York, and final no significant hazards consideration determination are contained in a Safety Evaluation dated February 21, 2003.

*Nuclear Management Company, LLC, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota*

*Date of application for amendment:* April 22, 2002, as supplemented September 16, 2002.

*Brief description of amendment:* The amendment changes the Technical Specifications by revising the curves for minimum pressure-temperature for the reactor pressure vessel. The P-T curves addressed by this amendment were