

Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by e-mail to pdr@nrc.gov.

AmerGen Energy Company, LLC, et al., Docket No. 50-219, Oyster Creek Nuclear Generating Station, Ocean County, New Jersey

Date of application for amendment: April 10, 2002.

Brief description of amendment: The amendment revised the Technical Specifications (TSs) to relocate emergency diesel generator maintenance inspection requirements from Section 4.7 to the Updated Final Safety Analysis Report.

Date of Issuance: March 7, 2003.

Effective date: March 7, 2003 shall be implemented within 30 days of issuance, except the relocation of the emergency diesel generator maintenance requirements of Technical Specification 4.7, which shall be incorporated into the Updated Final Safety Analysis Report in accordance with the schedule specified by 10 CFR 50.71.

Amendment No.: 236.

Facility Operating License No. DPR-16: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 28, 2002 (67 FR 36926).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 7, 2003.

No significant hazards consideration comments received: No.

Carolina Power & Light Company, et al., Docket No. 50-400, Shearon Harris Nuclear Power Plant, Unit 1, Wake and Chatham Counties, North Carolina

Date of application for amendment: August 30, 2002, as supplemented November 21 and December 16, 2002, and January 23, 2003.

Brief description of amendment: This amendment revises the Technical Specifications by eliminating the requirements to perform response time testing for several reactor protection system and engineered safety feature functions in conformance with previously approved topical reports.

Date of issuance: March 7, 2003.

Effective date: March 7, 2003.

Amendment No.: 112.

Facility Operating License No. NPF-63: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: November 1, 2002 (67 FR 61676).

The November 21 and December 16, 2002, and January 23, 2003, letters provided clarifying information and did not change the initial proposed no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 7, 2003.

No significant hazards consideration comments received: No.

Carolina Power & Light Company, et al., Docket No. 50-400, Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Wake and Chatham Counties, North Carolina

Date of application for amendment: August 28, 2002.

Brief description of amendment: This amendment revises Technical Specification (TS) 3/4.9.9, "Containment Ventilation Isolation System," to allow the same administrative controls for this TS as were approved previously by the NRC in Amendment No. 104 to the HNP TS for TS 3/4.9.4, "Containment Building Penetrations," to provide consistency between the two TS.

Date of issuance: March 12, 2003.

Effective date: March 12, 2003.

Amendment No.: 113.

Facility Operating License No. NPF-63: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: October 1, 2002 (67 FR 61676).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 12, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, et al., Docket No. 50-414, Catawba Nuclear Station, Unit 2, York County, South Carolina

Date of application for amendments: October 10, 2002, as supplemented by letters dated February 7 and February 26, 2003.

Brief description of amendments: The amendment authorizes the licensee to continue to use, for operational cycle 13 beginning in March 2003, and subsequent cycles of operation, the reactor coolant system cold leg elbow tap flow coefficients that were approved by the NRC on an interim basis for cycle 12 in Amendment No. 186.

Date of issuance: March 19, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 199.

Facility Operating License No. NPF-52: Amendment authorizes revision of the Updated Final Safety Analysis Report.

Date of initial notice in Federal Register: November 26, 2002 (67 FR 70765).

The supplements dated February 7 and February 26, 2003, provided clarifying information that did not change the scope of the October 10, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 19, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina

Date of application for amendments: May 29, 2002, as supplemented by letters dated September 25 and November 12, 2002, and January 8 and January 29, 2003.

Brief description of amendments: The amendments revised the Technical Specifications to allow a one-time change in the Appendix J, Type A containment integrated leakage rate test interval from the currently required 10-year interval to a test interval of 15 years.

Date of issuance: March 12, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 205/198.

Facility Operating License Nos. NPF-35 and NPF-52: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: July 9, 2002 (67 FR 45563).

The supplements dated September 25 and November 12, 2002, and January 8 and January 29, 2003, provided clarifying information that did not change the scope of the May 29, 2002, application or the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 12, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: May 29, 2002, as supplemented by letters dated September 25 and