

Effective date: As of the date of issuance, and shall be implemented within 60 days.

Amendment No.: 196.

Facility Operating License No. DPR-35: Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* November 12, 2002 (67 FR 68735).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 17, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-382, Waterford Steam Electric Station, Unit 3, St. Charles Parish, Louisiana

Date of amendment request: October 24, 2002, as supplemented by letter dated February 4, 2003.

Brief description of amendment: The amendment revises Technical Specifications (TSs) relating to positive reactivity additions while in shutdown modes by clarifying TSs involving positive reactivity additions. In addition, the borated water volume requirements in TS 3.1.2.7 is now presented in "percent level" units and an obsolete reference from Surveillance Requirement 4.8.2.2 is deleted.

Date of issuance: March 7, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 185.

Facility Operating License No. NPF-38: The amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* December 10, 2002 (67 FR 75874).

The February 4, 2003, supplemental letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 7, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-382, Waterford Steam Electric Station, Unit 3, St. Charles Parish, Louisiana

Date of amendment request: April 2, 2001, as supplemented by letters dated September 24, 2001, and February 27, July 31, and December 19, 2002.

Brief description of amendment: The Refueling Water Storage Pool (RWSP) purification system is aligned to the RWSP to maintain the purity and clarity of the borated water contained in the pool. It is also one of two means of

makeup to the Spent Fuel Pool, with the Condensate Storage Pool being the primary makeup source. Entergy Operations Inc. has proposed to revise its Waterford Steam Electric Station, Unit 3, Updated Final Safety Analysis Report (UFSAR) to allow the manual valves (FS-423 and FS-404) that isolate the RWSP from the RWSP purification system and provide the boundary between the seismically qualified, safety related RWSP and the non-seismic, non-safety related RWSP purification system to be maintained open.

Date of issuance: March 12, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 186.

Facility Operating License No. NPF-38: The amendment revised the UFSAR.

*Date of initial notice in **Federal Register**:* May 16, 2001 (66 FR 27176).

The September 24, 2001, and February 27, July 31, and December 19, 2002, supplemental letters provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 12, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Date of application for amendments: November 27, 2002.

Brief description of amendments: These amendments delete technical specification (TS) 5.5.3, "Post Accident Sampling," and thereby eliminate the requirements to have and maintain the post accident sampling system at the Dresden Nuclear Power Station, Units 2 and 3. The amendments also address related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

Date of issuance: March 11, 2003.

Effective date: As of the date of issuance and shall be implemented within 180 days.

Amendment Nos.: 197/190.

Facility Operating License Nos. DPR-19 and DPR-25: The amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* January 21, 2003 (68 FR 2802).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 11, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket No. 50-353, Limerick Generating Station, Unit 2, Montgomery County, Pennsylvania

Date of application for amendment: November 21, 2002, as supplemented February 25, 2003.

Brief description of amendment: This amendment revised the Technical Specifications (TSs) for the safety limit for the minimum critical power ratio from its current value of 1.09 to 1.07 for two recirculation-loop operations, and from 1.11 to 1.09 for single recirculation-loop operation.

Date of issuance: March 11, 2003.

Effective date: As of the date of issuance, to be implemented prior to startup for Cycle 8 operations, scheduled for March 2003.

Amendment No.: 127.

Facility Operating License No. NPF-85: The amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* January 7, 2003 (68 FR 802). The February 25, 2003, letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register** on January 7, 2003 (68 FR 802).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 11, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-254 and 50-265, Quad Cities Nuclear Power Station, Units 1 and 2, Rock Island County, Illinois

Date of application for amendments: November 27, 2002.

Brief description of amendments: These amendments delete technical specification (TS) 5.5.3, "Post Accident Sampling," and thereby eliminate the requirements to have and maintain the post accident sampling system at the Quad Cities Nuclear Power Station, Units 1 and 2. The amendments also address related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

Date of issuance: March 11, 2003.

Effective date: As of the date of issuance and shall be implemented within 180 days.

Amendment Nos.: 212/206.

Facility Operating License Nos. DPR-29 and DPR-30: The amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* January 21, 2003 (68 FR 2802)