

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 11, 2003.
No significant hazards consideration comments received: No.

FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit 1, Lake County, Ohio

Date of application for amendment: March 14, 2002, as supplemented by letters dated July 17 and September 12, 2002, and January 24, 2003.

Brief description of amendment: This amendment supplements License Amendment No. 100, which was issued on February 24, 1999, by placing restrictions on removing the inclined fuel transfer system (IFTS) blind flange during Operational Modes 1, 2, and 3. The amendment includes a time limit on the removal of the IFTS blind flange, provides a requirement to install the upper pool IFTS gate prior to IFTS blind flange removal, and limits the unbolted configuration of the IFTS blind flange when it is rotated.

Date of issuance: March 7, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment No.: 123.

Facility Operating License No. NPF-58: This amendment revised the Technical Specifications.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5675).

The supplemental information contained clarifying information that was within the scope of the original application and did not change the staff's initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 7, 2003.

No significant hazards consideration comments received: No.

FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit 1, Lake County, Ohio

Date of application for amendment: October 30, 2002.

Brief description of amendment: This amendment deletes Technical Specification (TS) 5.5.3, "Post Accident Sampling System (PASS)," and thereby eliminates the requirements to have and maintain the PASS at the Perry Nuclear Power Plant, Unit 1. The amendment also addresses related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

Date of issuance: March 7, 2003.

Effective date: As of the date of issuance and shall be implemented within 180 days.

Amendment No.: 124.

Facility Operating License No. NPF-58: This amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 21, 2003 (68 FR 2803).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 7, 2003.

No significant hazards consideration comments received: No.

GPU Nuclear Inc., Docket No. 50-320, Three Mile Island Nuclear Station, Unit 2, Dauphin County, Pennsylvania

Date of amendment request: November 14, 2002, supplemented by a letter dated January 24, 2003, that supersedes previous applications dated August 9, 2000, June 13, 2002.

Brief description of amendment request: The amendment revises TS 6.5.4 and 6.5.3 to eliminate the requirements for the Independent Onsite Safety Review Group (IOSRG) which is not needed for safe monitoring of TMI-2 based on consideration that the reactor has been defueled to the extent reasonably achievable and the fuel shipped offsite. The amendment also revises TS 6.4 to delete the requirements for unit staff training that are outdated based on the adoption of a systems approach to training consistent with 10 CFR 50.120, "Training and Qualification of Nuclear Power Plant Personnel."

Date of issuance: March 5, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 59.

Facility Operating License No. DPR-73: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: August 6, 2002 (67 FR 50955).

The November 14, 2002, application and supplemental letter dated January 24, 2003, replace in their entirety the previous applications dated August 9, 2000, June 13, 2002. The November 14, 2002, application supplemented by the January 24, 2003, letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a safety evaluation dated March 5, 2003.

No significant hazards consideration comments received: No.

Indiana Michigan Power Company, Docket No. 50-316, Donald C. Cook Nuclear Plant, Unit 2, Berrien County, Michigan

Date of application for amendment: July 23, 2002, as supplemented November 15, 2002, and January 24, 2003.

Brief description of amendment: The amendment revises the Unit 2 reactor coolant system pressure-temperature curves in Technical Specification (TS) Figures 3.4-2 and 3.4-3 and associated TS Bases. The revised curves will bound operation of the unit for the remainder of its current license duration and bound operation with planned license amendments to increase the power level at which the unit is allowed to operate.

Date of issuance: March 20, 2003.

Effective date: As of the date of issuance and shall be implemented prior to startup from Unit 2 refueling outage 14.

Amendment No.: 255.

Facility Operating License No. DPR-74: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: October 29, 2002 (67 FR 66010).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 20, 2003.

No significant hazards consideration comments received: No.

Maine Yankee Atomic Power Company, Docket No. 50-309, Maine Yankee Atomic Power Station, Lincoln County, Maine

Date of application for amendment: January 13, 2000, and supplemented by letters dated June 1, 2001, August 13, 2001, and October 15, 2002.

Brief description of amendment: The amendment adds License Condition 2.B.(9) to the MY license. This new license condition incorporates the, Nuclear Regulatory Commission (NRC) approved, "License Termination Plan Rev 3." (LTP), and associated addendum, into the MY license and allows the licensee to make certain changes to the approved LTP without prior NRC review and approval.

Date of issuance: February 28, 2003.

Effective date: Date of issuance; to be implemented within [30] days from the date of issuance.

Amendment No.: 168.