

Facility Operating License No. DPR-36: The amendment adds License Condition 2.B.(9).

*Date of initial notice in **Federal Register**:* March 19, 2002.

The supplemental letters provided additional clarifying information, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination published in the **Federal Register** on March 19, 2002.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation Report dated February 28, 2003.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska

Date of amendment request: September 26, 2002.

Brief description of amendment: The amendment revises Surveillance Requirement (SR) 3.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance. The delay period is extended from the current limit of " * * * up to 24 hours or up to the limit of the specified Frequency, whichever is less" to " * * * up to 24 hours or up to the limit of the specified Frequency, whichever is greater." In addition, the following requirement is added to SR 3.0.3: "A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed."

Date of issuance: March 6, 2003.

Effective date: March 6, 2003.

Amendment No.: 197.

Facility Operating License No. DPR-46: Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* December 10, 2002 (67 FR 75882).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 6, 2003.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska

Date of amendment request: November 15, 2002, as supplemented by letter dated February 24, 2003.

Brief description of amendment: The amendment revises the safety limit minimum critical power ratio values in Technical Specification 2.1.1.2.

Date of issuance: March 17, 2003.

Effective date: March 17, 2003.

Amendment No.: 198.

Facility Operating License No. DPR-46: Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* December 24, 2002 (67 FR 78521).

The supplemental letter provided clarifying information that was within the scope of the original **Federal Register** Notice (67 FR 78521) and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 17, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: July 26, 2002, as supplemented December 19, 2002.

Brief description of amendment: The amendment revises Technical Specification (TS) 1.0, "Definitions," TS 2.1, "Safety Limits, Reactor Core," TS 2.3, "Limiting Safety System Settings, Protective Instrumentation," TS 3.1, "Reactor Coolant System," TS 3.8, "Refueling Operations," TS 3.10, "Control Rod and Power Distribution Limits," TS 6.9, "Reporting Requirements," and their associated Bases. These modifications allow the licensee to implement a Core Operating Limits Report (COLR) by relocating cycle-specific, reactor coolant system-related parameter limits from the TSs to the COLR. In addition, the amendment makes administrative changes to the above TSs.

Date of issuance: March 11, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 165.

Facility Operating License No. DPR-43: Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* September 3, 2002 (67 FR 56322).

The supplemental information dated December 19, 2002, contained clarifying information and did not change the scope of the July 26, 2002, application nor the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 11, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: March 19, 2002, supplemented by letters dated September 13 and October 21, 2002.

Brief description of amendment: The amendment revises the current radiological consequence analyses for the Kewaunee Nuclear Power Plant (KNPP) design-basis accidents to implement the alternate source term (AST) as described in Regulatory Guide 1.183, "Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors" and Pursuant to 10 CFR 50.67, "Accident Source Term."

Date of issuance: March 17, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 166.

Facility Operating License No. DPR-43: Amendment revised the current radiological consequence analyses for the KNPP design-basis accidents to implement the AST.

*Date of initial notice in **Federal Register**:* April 16, 2002 (67 FR 18646).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 17, 2003.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey

Date of application for amendment: January 4, 2002, as supplemented January 9, 2003.

Brief description of amendment: The amendment adds a limiting condition for operation of the mechanical vacuum pump instrumentation to trip the pumps on indication of high radiation levels in the main steam line and adds associated Surveillance Requirements.

Date of issuance: March 11, 2003.

Effective date: As of date of issuance, to be implemented within 60 days.

Amendment No.: 143.

Facility Operating License No. NPF-57: This amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* February 19, 2002 (67 FR 7421).

The January 9, 2003, supplement contained clarifying information and