

did not change the staff's proposed finding of no significant hazards consideration. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 11, 2003.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey

Date of application for amendment: August 20, 2002.

Brief description of amendment: The amendment modifies the diesel generator action statements and surveillance requirements defined in the plant's Technical Specifications, in order to reduce degradation of the diesel generators associated with fast starting and rapid loading.

Date of issuance: March 17, 2003.

Effective date: March 17, 2003.

Amendment No.: 144.

Facility Operating License No. NPF-57: This amendment revised the Technical Specifications.

Date of initial notice in Federal Register: October 1, 2002 (67 FR 61684).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 17, 2003.

No significant hazards consideration comments received: No.

South Carolina Electric & Gas Company, South Carolina Public Service Authority, Docket No. 50-395, Virgil C. Summer Nuclear Station, Unit No. 1, Fairfield County, South Carolina

Date of application for amendment: March 20, 2002.

Brief description of amendment: The proposed amendment would change Technical Specification (TS) Section 1.10, "Definitions, Dose Equivalent I-131," to allow the use of the thyroid dose conversion factors listed in the International Commission on Radiological Protection Publication No. 30 (ICRP-30), "Limits for Intakes of Radionuclides by Workers," 1979, in determining the iodine-131 dose equivalent reactor coolant activity in TS Section 3/4.4.8 and in calculating the radiological consequences from postulated design basis accidents.

Date of issuance: March 6, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment No.: 162.

Facility Operating License No. NPF-12: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: August 20, 2002 (67 FR 53991).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 6, 2003.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Units 1 and 2, Appling County, Georgia

Date of application for amendments: August 9 2002, as supplemented by letters dated January 8 and February 6, 2003.

Brief description of amendments: The amendments revised the Updated Final Safety Analysis Report to incorporate the Boiling Water Reactor Vessel and Internals Project Integrated Surveillance for the surveillance of the material capsules.

Date of issuance: March 10, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 237 and 179.

Renewed Facility Operating License Nos. DPR-57 and NPF-5: Amendments revised the Updated Final Safety Analysis Report.

Date of initial notice in Federal Register: October 1, 2002 (67 FR 61684).

The supplements dated January 8 and February 6, 2003, provided clarifying information that did not change the scope of the August 9, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 10, 2003.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 24th day of March, 2003.

For the Nuclear Regulatory Commission.

John A. Zwolinski,

Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 03-7489 Filed 3-31-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Appointments to Performance Review Boards for Senior Executive Service

AGENCY: Nuclear Regulatory Commission.

ACTION: Appointment to Performance Review Boards for Senior Executive Service.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) has announced the following appointments to the NRC Performance Review Boards.

The following individuals are appointed as members of the NRC Performance Review Board (PRB) responsible for making recommendations to the appointing and awarding authorities on performance appraisal ratings and performance awards for Senior Executives and Senior Level employees:

Patricia G. Norry, Deputy Executive Director for Management Services, Office of the Executive Director for Operations.
R. William Borchardt, Associate Director for Inspection and Programs, Office of Nuclear Reactor Regulation.
Stephen G. Burns, Deputy General Counsel, Office of the General Counsel.
Frank J. Congel, Director, Office of Enforcement.
James E. Dyer, Regional Administrator, Region III.
Jesse L. Funches, Chief Financial Officer.
Scott F. Newberry, Director, Division of Risk Analysis and Applications, Office of Nuclear Regulatory Research.
James B. Schaeffer, Director, Applications Development Division, Office of the Chief Information Officer.
Michael L. Springer, Director, Office of Administration.
Martin J. Virgilio, Director, Office of Nuclear Material Safety and Safeguards.
Michael F. Weber, Deputy Director, Office of Nuclear Security and Incident Response.
The following individuals will serve as members of the NRC PRB Panel that was established to review appraisals and make recommendations to the appointing and awarding authorities for NRC PRB members:
Karen D. Cyr, General Counsel, Office of the General Counsel.
William F. Kane, Deputy Executive Director for Reactor Programs, Office of the Executive Director for Operations.