

should be analyzed in the EA. The times and locations of these meetings are as follows:

#### Public Scoping Meeting

*Date:* Tuesday, May 6, 2003.

*Time:* 7 p.m.–9 p.m.

*Place:* Hagerman Senior and Community Center.

*Address:* 140 East Lake, Hagerman, Idaho.

#### Agency Scoping Meeting

*Date:* Wednesday, May 7, 2003

*Time:* 9:30 a.m.–noon

*Place:* Idaho Power Company Headquarters Building

*Address:* 1221 West Idaho, Bosie, Idaho

Copies of the Scoping Document (SD1) outlining the subject areas to be addressed in the EA were distributed to the parties on the Commission's mailing list. Copies of the SD1 will be available at the scoping meeting or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "FERRIS" link. Enter the docket number excluding the last three digits in the docket field to access the document. For assistance, contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov) or toll free at 1-866-208-3676, or for TTY, (202) 502-8659. A copy is also available for inspection at the address in item "h" above.

#### Site Visit

The Applicant and FERC staff will conduct a project site visit beginning at 1 p.m. on Tuesday, May 6, 2003. All interested individuals, organizations, and agencies are invited to attend. All participants should meet at Idaho Power's Hagerman Maintenance Shop located just south of the Malad River Bridge, off Highway 30 north of Hagerman. All participants are responsible for their own transportation to the site. RSVP Lewis Wardle, Idaho Power Company, at (208) 388-2964, if you plan to attend the site visit.

#### Objectives

At the scoping meetings, the staff will: (1) Summarize the environmental issues tentatively identified for analysis in the EA; (2) solicit from the meeting participants all available information, especially quantifiable data, on the resources at issue; (3) encourage statements from experts and the public on issues that should be analyzed in the EA, including viewpoints in opposition to, or in support of, the staff's preliminary views; (4) determine the resource issues to be addressed in the EA; and (5) identify those issues that require a detailed analysis, as well as

those issues that do not require a detailed analysis.

#### Procedures

The meetings are recorded by a stenographer and become part of the formal record of the Commission proceeding on the project.

Individuals, organizations, and agencies with environmental expertise and concerns are encouraged to attend the meeting and to assist the staff in defining and clarifying the issues to be addressed in the EA.

**Magalie R. Salas,**

*Secretary.*

[FR Doc. 03-7867 Filed 4-1-03; 8:45 am]

BILLING CODE 6717-01-P

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

[Project Nos.477-024]

#### Notice of Intent To Prepare an Environmental Impact Statement and Soliciting Additional Scoping Comments

March 26, 2003.

Take notice that the following hydroelectric applications have been filed with Commission and are available for public inspection:

a. *Application Type:* Amendment of License, Surrender of License, Settlement Agreement and Decommissioning Plan.

b. *Project No.:* 477-024.

c. *Date Filed:* November 12, 2002.

d. *Applicant:* Portland General Electric Company (PGE).

e. *Name of Project:* Bull Run Hydroelectric Project.

f. *Location:* On the Sandy, Little Sandy, and Bull Run Rivers, near the Town of Sandy, Clackamas County, Oregon. The project is located on lands administered by the Forest Service (Mt. Hood National Forest) and the Bureau of Land Management.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791(a)-825(r); Rule 602 of the Commission's Rules of Practice and Procedure, 18 CFR 385.602.

h. *Applicant Contact:* Julie A. Keil, Director, Hydro Licensing and Water Rights, PGE, 121 SW Salmon Street, Portland, Oregon 97204, 503-464-8864.

i. *FERC Contact:* Alan Mitchnick, 202-502-6074;

[alan.mitchnick@ferc.gov](mailto:alan.mitchnick@ferc.gov).

j. *Deadline for filing additional scoping comments:* 30 days from date of this notice.

All documents (original and eight copies) should be filed with: Magalie R.

Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

The Commission's Rules of Practice and Procedure require all interveners filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervener files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

Scoping comments may be filed electronically via the Internet in lieu of paper. The Commission strongly encourages electronic filings. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site (<http://www.ferc.gov>) under the "e-Filing" link.

k. *Amendment Application:* PGE proposes to: (i) Extend the term of the license from November 16, 2004, to November 16, 2017; (ii) continue generation until removal of the Little Sandy dam in 2008; (iii) implement a program of geomorphological and water quality monitoring continuing until Marmot dam removal; (iv) continue operation of the fish ladder and sorting facility at Marmot dam until Marmot dam removal; and (v) modify the operation of the diversion canal at Marmot dam to provide protection of threatened fish species from November 2004 until November 2007.

*Surrender Application:* The Project works include: Marmot dam, located at River Mile (RM) 30 on the Sandy River; a 3.1-mile-long series of canals and tunnels leading from Marmot dam to the Little Sandy River just upstream of the Little Sandy diversion dam; the Little Sandy diversion dam, located at RM 1.7 on the Little Sandy River; a 2.8-mile-long box flume leading from the Little Sandy diversion dam to the manmade forebay, Roslyn Lake; two 1,200 foot penstocks; and a powerhouse containing four generators with a total capacity of 22 megawatts. The powerhouse discharges to the Bull Run River 1.5 miles above its confluence with the Sandy River at RM 18.4.

PGE proposes the complete removal of both Marmot and the Little Sandy diversion dams, starting in 2007, along with the dismantling of their associated water conveyance structures. In addition, Roslyn Lake would be drained, the powerhouse generating equipment would be disabled, and the powerhouse structure would be demolished. All PGE-owned lands within the existing project boundary would be conveyed to the Western