

TABLE 2.A TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS IN THE LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For...	That is controlled with...	You must meet these operating limits...
	c. A wet scrubber .....	Maintain the minimum pH, pressure drop, and liquid flow-rate at or above the operating levels established during the performance test according to provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter, mercury, and hydrogen chloride or the levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for hydrogen chloride, mercury, and the alternative total selected metals emission limit.
	d. A wet scrubber in combination with a fabric filter.	i. Maintain the minimum pH, pressure drop, and liquid flow-rate of the wet scrubber at or above the operating levels established during the performance test according to provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter, hydrogen chloride, and mercury or the levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for hydrogen chloride, mercury, and the alternative total selected metals emission limit; and ii. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained.
	e. A wet scrubber in combination with an electrostatic precipitator.	Maintain the minimum pH, pressure drop, and liquid flow-rate of the wet scrubber and the minimum voltage and secondary current or total power input of the electrostatic precipitator at or above the operating levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter, hydrogen chloride, and mercury or the levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for hydrogen chloride, mercury, and the alternative total selected metals emission limit.
	f. A dry scrubber .....	i. Maintain the minimum sorbent injection rate of the dry scrubber at or above the operating levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride emissions; and ii. Maintain opacity to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter and mercury emissions or the opacity level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the alternative emission limits for total selected metals and the mercury emission limit.