

TABLE 2.A TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS IN THE LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For...	That is controlled with...	You must meet these operating limits...
	g. A dry scrubber in combination with a fabric filter.	i. Maintain minimum sorbent injection rate of the dry scrubber at or above the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride emissions; and ii. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained.
2. Each new or reconstructed industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory, the limited use solid fuel subcategory, or the small solid fuel subcategory that is complying with the alternative total selected metals emission limit instead of the particulate matter emission limit (this is an option for those units that can demonstrate compliance on the basis of fuel analysis without controls).	a. Either no add-on controls or add-on controls for which you do not wish to take credit for any emission reduction of total selected metals or mercury.	i. Maintain the fuel total selected metals content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for total selected metals; and ii. Maintain the fuel chlorine content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride; and iii. Maintain the fuel mercury content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for mercury.
3. Each existing industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory.	a. An add-on control other than a wet scrubber or a dry scrubber. b. A fabric filter either alone or in combination with an add-on control other than a wet scrubber or a dry scrubber. c. A wet scrubber	i. Maintain opacity to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter and mercury or the opacity level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the alternative emission limit for total selected metals and the mercury emission limit; and ii. Maintain the fuel chlorine content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride. i. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained; and ii. Maintain the fuel chlorine content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride. Maintain the minimum pH, pressure drop, and liquid flow-rate at or above the operating levels established during the performance test according to provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter, hydrogen chloride, and mercury emissions or the levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for hydrogen chloride, mercury, and the alternative total selected metals emission limit.