

TABLE 2.A TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS IN THE LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For...	That is controlled with...	You must meet these operating limits...
	e. A wet scrubber in combination with an electrostatic precipitator.	Maintain the minimum pressure drop and liquid flow-rate of the wet scrubber and the minimum voltage and secondary current of the electrostatic precipitator at or above the operating levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for particulate matter emissions or the levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the alternative total selected metals emission limit.
6. Each existing industrial, commercial, or institutional boiler or process heater in the limited use solid fuel subcategory that is complying with the alternative total selected metals emission limit instead of the particulate matter emission limit (this is an option for those units that can demonstrate compliance on the basis of fuel analysis without controls).	Either no add-on controls for which you do not wish to take credit for any emission reduction of total selected metals.	Maintain the fuel total selected metals content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for total selected metals.

As stated in § 63.7500, you must comply with the following applicable operating limits:

TABLE 2.B TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS IN THE LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES

For...	That is controlled with...	You must meet these operating limits...
1. Each new or reconstructed industrial, commercial, institutional boiler or process heater in the large liquid fuel subcategory, the limited use liquid fuel subcategory, or the small liquid fuel subcategory (boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and gases and do not burn any residual oil are excluded from this operating limit).	<p>a. An add-on control other than a wet scrubber or a dry scrubber.</p> <p>b. A fabric filter either alone or in combination with an add-on control other than a wet scrubber or a dry scrubber.</p> <p>c. A wet scrubber</p> <p>d. A wet scrubber in combination with a fabric filter.</p>	<p>i. Maintain opacity to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for particulate matter; and</p> <p>ii. Maintain the fuel chlorine content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride.</p> <p>i. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained; and</p> <p>ii. Maintain the fuel chlorine content to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride.</p> <p>Maintain the minimum pH, pressure drop, and liquid flow-rate at or above the operating levels established during the performance test according to provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter emissions and hydrogen chloride emissions.</p> <p>i. Maintain the minimum pH, pressure drop, and liquid flow-rate of the wet scrubber at or above the operating levels established during the performance test according to provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter emissions and hydrogen chloride emissions; and</p> <p>ii. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained.</p>