

TABLE 2.B TO SUBPART DDDDD OF PART 63—OPERATING LIMITS FOR BOILERS AND PROCESS HEATERS IN THE LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	You must meet these operating limits . . .
	e. A wet scrubber in combination with an electrostatic precipitator.	Maintain the minimum pH, pressure drop, and liquid flow-rate of the wet scrubber and the minimum voltage and secondary current or total power input of the electrostatic precipitator at or above the operating levels established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for particulate matter emissions and hydrogen chloride emissions.
	f. A dry scrubber .....	i. Maintain the minimum sorbent injection rate of the dry scrubber at or above the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limits for hydrogen chloride emissions; and ii. maintain opacity to less than or equal to the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for particulate matter emissions.
	g. A dry scrubber in combination with a fabric filter.	i. Maintain the minimum sorbent injection rate of the dry scrubber at or above the operating level established during the performance test according to the provisions in § 63.7530(c) that demonstrated compliance with the emission limit for hydrogen chloride emissions; and ii. Maintain the fabric filter operation such that the operating limit established for fabric filters in § 63.7530(c)(6)(v) is maintained.

As stated in § 63.7500, you must comply with the following applicable work practice standards:

TABLE 3 TO SUBPART DDDDD OF PART 63—WORK PRACTICE STANDARDS

For each . . .	You must . . .
1. New or reconstructed industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory, the large liquid fuel subcategory, or the large gaseous fuel subcategory.	Continuously monitor carbon monoxide emissions according to the procedures in § 63.7525(a) to maintain carbon monoxide emissions at or below an exhaust concentration of 400 ppm by volume on a dry basis corrected to 3 percent oxygen. The averaging time shall be 1 calendar day.
2. New or reconstructed industrial, commercial, or institutional boiler or process heater in the limited use solid fuel subcategory, the limited use liquid fuel subcategory, or the limited use gaseous fuel subcategory.	Continuously monitor carbon monoxide emissions according to the procedures in § 63.7525(a) to maintain carbon monoxide emissions at or below an exhaust concentration of 400 ppm by volume on a dry basis corrected to 3 percent oxygen. The averaging time shall be 1 calendar day.

As stated in § 63.7520, you must comply with the following requirements for performance test for existing, new or reconstructed affected sources:

TABLE 4.A TO SUBPART DDDDD OF PART 63—REQUIREMENTS FOR PERFORMANCE TESTS FOR PARTICULATE MATTER EMISSIONS OR TOTAL SELECTED METALS EMISSIONS FROM BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES

For . . .	That is controlled with . . .	You must . . .	Using . . .	According to the following requirements . . .
1. Each new reconstructed, or existing industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory, the limited use solid fuel subcategory, or the small solid fuel subcategory.	a. Any type of device .....	1. Select sampling ports location and the number of traverse points.	Method 1 of 40 CFR part 60, appendix A.	