

TABLE 5.A TO SUBPART DDDDD OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS FOR PARTICULATE MATTER OR TOTAL SELECTED METALS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
	d. A wet scrubber in combination with an electrostatic precipitator.	i. 0.026 lb particulate matter per MMBtu heat input or 0.0001 lb total selected metals per MMBtu heat input.	<p>(2) You keep a record of the average site-specific pressure drop and liquid flow-rate of the wet scrubber for each test run over the three-run performance test during which particulate matter or total selected metals emissions did not exceed the emissions limit; and</p> <p>(3) You keep records of the installation and calibration data and the manufacturers certification of the bag leak detection system as required in § 63.7525(i).</p> <p>(1) The average emissions in units of lb particulate matter per MMBtu heat input, measured using PM emissions concentration and sections 12.2 and 12.3 of Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; or the average emissions in units of lb total selected metals per MMBtu heat input measured using total selected metals emission concentration and sections 12.2 and 12.3 of Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and</p> <p>(2) You keep a record of the average site-specific pressure drop and liquid flow-rate of the wet scrubber and the average secondary current and voltage or total power input of the electrostatic precipitator for each test run.</p>
2. Each new or reconstructed industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory, the limited use solid fuel subcategory, or the small solid fuel subcategory that is complying with the alternative total selected metals emission limit instead of the particulate matter emission limit (this is an option for those units that can demonstrate compliance on the basis of fuel analysis without controls).	a. Either no add-on controls or an add-on control for which you do not wish to take credit for reductions in total selected metals.	i. 0.0001 lb total selected metals per MMBtu heat input.	<p>(1) The calculated emissions using Equation 2 of § 63.7530(c) and converted to lb total selected metals per MMBtu heat input does not exceed the emission limit; and</p> <p>(2) You keep a record of the fuel analysis, calculations, and the maximum fuel total selected metals input at which you demonstrated compliance.</p>