

TABLE 5.A TO SUBPART DDDDD OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS FOR PARTICULATE MATTER OR TOTAL SELECTED METALS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
4. Each existing industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory or the limited use solid fuel subcategory that is complying with the alternative total selected metals emission limit instead of the particulate matter emission limit (this is an option for those units that can demonstrate compliance on the basis of fuel analysis without controls).	a. Either no add-on controls or an add-on control for which you do not wish to take credit for reductions in total selected metals.	i. 0.001 lb total selected metals per MMBtu heat input.	(1) The calculated emissions using Equation 2 of §63.7530(c) and converted to lb total selected metals per MMBtu heat input does not exceed the emission limit; and (2) You keep a record of the fuel analysis, calculations, and the maximum fuel total selected metals input at which you demonstrated compliance.

As stated in § 63.7530, you must show initial compliance with the emission limitations for affected sources according to the following:

TABLE 5.B TO SUBPART DDDDD OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS FOR PARTICULATE MATTER FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES

For . . .	That is controlled with . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
1. Each new or reconstructed industrial, commercial, or institutional boiler or process heater in the large liquid fuel subcategory, the limited use liquid fuel subcategory or the small liquid fuel subcategory (boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and other gases and do not burn any residual oil are excluded from this requirement).	a. Either no reconstructed add-on controls or an add-on control other than a scrubber.	i. 0.03 lb particulate matter per MMBtu heat input.	(1) The average emissions in units of lb particulate matter per MMBTU heat input, measured using PM emissions concentration and sections 12.2 and 12.3 of Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and (2) You keep a record of the average site-specific opacity level for each test run over the three-run performance test during which particulate matter emissions did not exceed the emissions limit; or if the unit is controlled with a fabric filter, instead of establishing a site-specific opacity level you keep records of the installation and calibration data and the manufacturer's certification of the bag leak detection system as required in §63.7525(i).
	b. A wet scrubber .....	i. 0.03 lb particulate matter per MMBtu heat input.	(1) The average emissions in units of lb particulate matter per MMBtu heat input, measured using PM emissions concentration and sections 12.2 and 12.3 of Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and (2) You keep a record of the average site-specific pressure drop and liquid flow-rate of the wet scrubber for each test run over the three-run performance test during which particulate matter emissions did not exceed the emissions limit.