

TABLE 5.C TO SUBPART DDDDD OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS FOR HYDROGEN CHLORIDE FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
	c. A dry scrubber .....	i. 0.09 lb hydrogen chloride per MMBtu heat input.	(1) The average emissions in units of lb hydrogen chloride per MMBtu heat input, measured using hydrogen chloride emissions concentration and Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and (2) You keep a record of the average site-specific sorbent injection rate of the dry scrubber for each test run over the three-run performance test during which hydrogen chloride emissions did not exceed the emissions limit.

As stated in § 63.7530, you must show initial compliance with the emission limitations for affected sources according to the following:

TABLE 5.D TO SUBPART DDDDD OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS FOR HYDROGEN CHLORIDE FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES

For . . .	That is controlled with . . .	For the following emission limitation . . .	You have demonstrated initial compliance if . . .
1. Each new or reconstructed commercial, or industrial, boiler or process heater in the liquid fuel subcategory (boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and other gases and do not burn any residual oil are excluded from this requirement).	a. Either no add-on controls or an add-on control other than a wet scrubber or a dry scrubber.	i. 0.0005 lb hydrogen chloride per MMBtu heat input.	(1) The average emissions in units of lb hydrogen chloride per MMBtu heat input, measured using hydrogen chloride emissions concentration and Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and (2) You keep a record of the average site-specific fuel chlorine content level for each test run over the three-run performance test during which hydrogen chloride emissions did not exceed the emissions limit.
	b. A wet scrubber .....	i. 0.0005 lb hydrogen chloride per MMBtu heat input.	(1) The average emissions in units of lb hydrogen chloride per MMBtu heat input, measured using hydrogen chloride emissions concentration and Method 19 of appendix A over the three-run performance test period, do not exceed the emission limit; and (2) You keep a record of the average site-specific pH, pressure drop, and liquid flow-rate of the wet scrubber for each test run over the three-run performance test during which hydrogen chloride emissions did not exceed the emissions limit.