

TABLE 7.A TO SUBPART DDDDD OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES

For . . .	That is controlled with . . .	For the following emission limitation . . .	You must demonstrate continuous compliance by . . .
1. Each new or reconstructed industrial, commercial, or institutional boiler or process heater in the large solid fuel subcategory, the limited use solid fuel subcategory, or the small solid fuel subcategory.	a. Either no add-on controls or an add-on control other than a wet scrubber or dry scrubber.	i. Opacity levels must not exceed the operating limit set during the PM or total selected metals and mercury performance tests and fuel chlorine content must not exceed the maximum operating limit set during the hydrogen chloride performance test according to the procedures in § 63.7530(c).	(1) Collecting the opacity monitoring system data according to §§ 63.7525(b) and 63.7535; and (2) Reducing the opacity monitoring data to 6-minute averages; and (3) Maintaining the 3-hour block average opacity levels at or below the limit established during the performance test; or if the unit is controlled with a fabric filter, instead of maintaining opacity maintaining the operation of the fabric filter such that the requirements in § 63.7540(a)(9) are met; and (4) Keeping daily records of fuel use and following the procedures in § 63.7540(a) and, therefore, maintaining the fuel chlorine content level at or below the limit set during the performance test.
	b. A wet scrubber .....	i. pH, pressure drop, and liquid flow-rate must be greater than or equal to the minimum operating limits set during the performance test.	(1) Collecting the pH, pressure drop, and liquid flow-rate monitoring system data according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average pH, pressure drop, and liquid flow-rate levels at or above the limits established during the performance test.
	c. A wet scrubber in combination with a fabric filter.	i. pH, pressure drop, and liquid flow-rate for the wet scrubber and pressure drop for the fabric filter must be greater than or equal to the minimum operating limits set during the performance test.	(1) Collecting the pH, pressure drop, and liquid flow-rate monitoring system data for the wet scrubber and the pressure drop monitoring system data for the fabric filter according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average pH, pressure drop, and liquid flow-rate of the wet scrubber and the 3-hour average pressure drop of the fabric filter at or above the limits established during the performance test; and (4) Maintaining the fabric filter operation such that the requirements in 63.7540(a)(9) are met.