

TABLE 7.A TO SUBPART DDDDD OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL SOLID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	For the following emission limitation . . .	You must demonstrate continuous compliance by . . .
	e. A dry scrubber	i. Opacity levels must not exceed the operating limit set during the performance test.	(1) Collecting the opacity monitoring system data according to §§ 63.7525(b) and 63.7535; and (2) Reducing the opacity monitoring data to 6-minute averages; and (3) Maintaining the 3-hour block average opacity levels at or below the limit established during the performance test.
8. Each existing industrial commercial, and institutional boiler or process in the limited use solid fuel subcategory that is complying with the alternative total selected metals emission limit instead of the particulate matter emission limit (this is an option for those that can demonstrate compliance on the basis of fuel analysis without controls).	Either no add-on controls or an add-on control for which you do not wish to take credit for reductions in total selected metals.	Fuel total selected metals content must not exceed the operating limit set during the performance test according to the provisions in § 63.7530(a).	Keeping daily records of fuel use and following the procedures in § 63.7540(a) and, therefore, maintaining the fuel total selected metals content level at or below the limit set during the performance test.

As stated in § 63.7540, you must show continuous compliance with the emission limitation for affected sources according to the following:

TABLE 7.B TO SUBPART DDDDD OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES

For . . .	That is controlled with . . .	For the following emission limitation . . .	You must demonstrate continuous compliance by . . .
1. Each new or reconstructed industrial, commercial, or institutional boiler or process heater in the large liquid fuel subcategory, the limited use liquid fuel subcategory, or the small liquid fuel subcategory (boilers or process heaters in one of the liquid fuel subcategories that burn only fossil fuels and gases and do not burn any residual oil are excluded from this requirement).	a. Either no add-on controls or an add-on control other than a wet scrubber or a dry scrubber.	i. Opacity levels must not exceed the operating limit set during the performance test and fuel chlorine content must not exceed the maximum operating limit set during the performance test according to the procedures in § 63.7530(c).	(1) Collecting the opacity monitoring system data according to §§ 63.7525(b) and 63.7535; and (2) Reducing the opacity monitoring data to 6-minute averages; and (3) Maintaining the 3-hour block average opacity levels at or below the limit established during the performance test; or if the unit is controlled with a fabric filter, instead of maintaining opacity maintaining the operation of the fabric filter such that the requirements in § 63.7540(a)(9) are met; and (4) Keeping daily records of fuel use and following the procedures in § 63.7540(a) and, therefore, maintaining the fuel chlorine content level at or below the limit set during the performance test.
	b. A wet scrubber	i. pH, pressure drop, and liquid flow-rate must be greater than or equal to the minimum operating limits set during the performance test.	(1) Collecting the pH, pressure drop, and liquid flow-rate monitoring system data according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average pH, pressure drop, and liquid flow-rate levels at or above the limits established during the performance test.