

TABLE 7.B TO SUBPART DDDDD OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS FOR BOILERS OR PROCESS HEATERS IN LARGE, LIMITED USE, OR SMALL LIQUID FUEL SUBCATEGORIES—Continued

For . . .	That is controlled with . . .	For the following emission limitation . . .	You must demonstrate continuous compliance by . . .
	c. A wet scrubber in combination with a fabric filter.	i. pH, pressure drop, and liquid flow-rate for the wet scrubber and pressure drop for the fabric filter must be greater than or equal to the minimum operating limits set during the performance test.	(1) Collecting the pH, pressure drop, and liquid flow-rate monitoring system data for the wet scrubber and the pressure drop monitoring system data for the fabric filter according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average pH, pressure drop, and liquid flow-rate of the wet scrubber and the 3-hour average pressure drop of the fabric filter at or above the limits established during the performance test; and (4) Maintaining the operation of the fabric filter such that the requirements in § 63.7540(a)(9) are met.
	d. A wet scrubber in combination with an electrostatic precipitator.	i. pH, pressure drop, and liquid flow-rate for the wet scrubber and secondary current and voltage or total power input for the electrostatic precipitator must be greater than or equal to the minimum operating limits set during the performance test.	(1) Collecting the pH, pressure drop, and liquid flow-rate monitoring system data for the wet scrubber and the secondary current and voltage monitoring system data or total power input data for the electrostatic precipitator according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average pH, pressure drop, and liquid flow-rate of the wet scrubber and the 3-hour average secondary current and voltage or total power input of the electrostatic precipitator at or above the limits established during the performance test.
	e. A dry scrubber	i. Sorbent injection rate of the dry scrubber must be greater than or equal to the minimum operating limits set during the performance test and opacity levels must not exceed the operating limit set during the performance test.	(1) Collecting the sorbent injection rate monitoring system data according to §§ 63.7525 and 63.7535; and (2) Reducing the data to 3-hour block averages; and (3) Maintaining the 3-hour average sorbent injection rate levels at or above the limits established during the performance test; and (4) Collecting the opacity monitoring system data according to § 63.7525(b) and reducing the opacity monitoring data to 6-minute averages and maintaining the 3-hour average opacity levels at or below the limit established during the performance test.