

TABLE 10 TO SUBPART DDDDD OF PART 63—APPLICABILITY OF GENERAL PROVISIONS TO SUBPART DDDDD—Continued

Citation	Subject	Brief description	Explanation
		ii. Reporting requirements for SSM when action is described in SSM plan.	Yes.
§ 63.8(c)(1)(ii)	SSM not in SSMP	Reporting requirements SSM when action is not described in SSM plan.	Yes.
§ 63.8(c)(1)(iii)	Compliance with Operation and Maintenance Requirements.	i. How Administrator determines if source complying with operation and maintenance requirements; and ii. Review of source O&M procedures, records, Manufacturer's instructions, recommendations, and inspection of monitoring system.	Yes. Yes.
§ 63.8(c)(2)–(3)	Monitoring System Installation	i. Must install to get representative emission and parameter measurements; and ii. Must verify operational status before or at performance test.	Yes. Yes.
§ 63.8(c)(4)	Continuous Monitoring System (CMS) Requirements.	Continuous monitoring systems must be operating except during breakdown, out-of-control, repair, maintenance, and high-level calibration drifts.	No.
§ 63.8(c)(4)(i)	Continuous Monitoring System (CMS) Requirements.	Continuous opacity monitoring system must have a minimum of one cycle of sampling and analysis for each successive 10-second period and one cycle of data recording for each successive 6-minute period.	Yes.
§ 63.8(c)(4)(ii)	Continuous Monitoring System (CMS) Requirements.	Continuous emissions monitoring system must have a minimum of one cycle of operation for each successive 15-minute period.	No.
§ 63.8(c)(7)–(8)	Continuous monitoring systems Requirements.	Out-of-control periods, including reporting	Yes.
§ 63.8(d)	Continuous monitoring systems Quality Control.	i. Requirements for continuous monitoring systems quality control, including calibration, etc.; and ii. Must keep quality control plan on record for the life of the affected source. Keep old versions for 5 years after revisions.	Yes. Yes.
§ 63.8(e)	Continuous monitoring systems Performance Evaluation.	Notification, performance evaluation test plan, reports	Yes.
§ 63.8(f)(1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring.	Yes.
§ 63.8(f)(6)	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for continuous emissions monitoring system.	No.
§ 63.8(g)(1)–(4)	Data Reduction	i. Continuous opacity monitoring system 6-minute averages calculated over at least 36 evenly spaced data points; and ii. Continuous emissions monitoring system 1-hour averages computed over at least 4 equally spaced data points.	Yes. Yes.
§ 63.8(g)(5)	Data Reduction	Data that cannot be used in computing averages for continuous emissions monitoring system and continuous opacity monitoring system.	No.
§ 63.9(a)	Notification Requirements	Applicability and State Delegation	Yes.
§ 63.9(b)(1)–(5)	Initial Notifications	i. Submit notification 120 days after effective date; and ii. Notification of intent to construct/reconstruct; and iii. Notification of commencement of construct/reconstruct; Notification of startup; and iv. contents of each	Yes. Yes. Yes. Yes.