

for two recirculation loop operation and from 1.10 to 1.13 for single recirculation loop operation.

*Date of issuance:* March 25, 2003.

*Effective date:* March 25, 2003.

*Amendment No.:* 254.

*Facility Operating License No. DPR-62:* Amendment changes the Technical Specifications.

*Date of initial notice in Federal Register:* December 10, 2002 (67 FR 75869). The February 17, 2003, supplement contained clarifying information only and did not change the initial no significant hazards consideration determination or expand the scope of the initial **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 25, 2003.

*No significant hazards consideration comments received:* No.

*Carolina Power & Light Company, et al., Docket No. 50-400, Shearon Harris Nuclear Power Plant, Unit 1, Wake and Chatham Counties, North Carolina*

*Date of application for amendment:* August 28, 2002, as supplemented November 21, 2002.

*Brief description of amendment:* This amendment revises the Technical Specifications (TS) by adding Topical Report EMF-2328 (P)(A), "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based" as reference in the TS to allow the licensee to update the methodologies that are used for safety analyses for the Shearon Harris Nuclear Power Plant, Unit 1. The amendment also relocates referenced methodologies within TS 6.9.1.6.2 to group mechanical design methodologies together.

*Date of issuance:* March 28, 2003.

*Effective date:* March 28, 2003.

*Amendment No.:* 114.

*Facility Operating License No. NPF-63:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* October 15, 2002 (67 FR 63691). The November 21, 2002, supplement contained clarifying information only and did not change the initial proposed no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 28, 2003.

*No significant hazards consideration comments received:* No.

*Detroit Edison Company, Docket No. 50-341, Fermi 2, Monroe County, Michigan*

*Date of application for amendment:* May 23, 2002, as supplemented

December 20, 2002, and February 27, 2003.

*Brief description of amendment:* The amendment revises the Fermi 2 Technical Specifications (TSs) to allow a one-time deferral of the Type A primary containment integrated leak rate test. Specifically, TS 5.5.12, "Primary Containment Leakage Rate Testing Program," would be revised to extend the current interval for performing the containment Type A test to 15 years.

*Date of issuance:* March 27, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment No.:* 153.

*Facility Operating License No. NPF-43:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* June 25, 2002 (67 FR 42817). The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 27, 2003.

*No significant hazards consideration comments received:* No.

*Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut*

*Date of application for amendment:* November 6, 2001, as supplemented on December 27, 2001, and July 15, August 6, and October 29, 2002.

*Brief description of amendment:* The amendment revises the Technical Specifications (TSs) associated with the spent fuel pool (SFP). Specifically, the amendment increases the allowable nominal average fuel assembly enrichment from 4.5 weight percent (w/o) Uranium-235 (U-235) to 4.85 w/o U-235 for all regions of the SFP, the new fuel storage racks (dry), and the reactor core; allows fuel to be located in the 40 storage cells in Region B of the SFP that are currently empty and blocked; credits SFP soluble boron for reactivity control during normal conditions; and reduces the Boraflex reactivity credit in Regions A and B of the SFP.

*Date of issuance:* April 1, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment No.:* 274.

*Facility Operating License No. DPR-65:* This amendment revised the TSs.

*Date of initial notice in Federal Register:* February 19, 2002 (67 FR

7414). The supplement dated December 27, 2001, provided a revision to the licensee's analysis of the issue of no significant hazards consideration, as originally provided in the November 6, 2001, application. The supplements dated July 15, August 6, and October 29, 2002, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 1, 2003.

*No significant hazards consideration comments received:* No.

*Entergy Nuclear Operations, Inc., Docket No. 50-286, Indian Point Nuclear Generating Unit No. 3, Westchester County, New York*

*Date of application for amendment:* June 3, 2002, as supplemented on January 23, 2003.

*Brief description of amendment:* The amendment revises Technical Specification (TS) 3.4.9, "Pressurizer," to increase the pressurizer water level limit when the plant is in MODE 3 (Hot Standby). The pressurizer water level limit for MODES 1 and 2 (Power Operation and Startup) remains unchanged. The amendment also revises TS 3.8.4, "DC Sources—Operating," to remove the notes that refer to the one-time amendment allowing the online replacement of station batteries 31 and 32. The notes were no longer applicable since the batteries have been replaced.

*Date of issuance:* March 25, 2003.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 216.

*Facility Operating License No. DPR-64:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 9, 2002 (67 FR 45566).

The January 23 letter provided clarifying information that did not enlarge the scope of the original **Federal Register** notice or change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 25, 2003.

*No significant hazards consideration comments received:* No.