

Entergy Nuclear Operations, Inc., Docket No. 50-293, Pilgrim Nuclear Power Station, Plymouth County, Massachusetts

Date of application for amendment: December 4, 2002, which replaces the original applications dated May 1, 2002.

Brief description of amendment: The proposed amendment would change the Pilgrim Nuclear Power Station Technical Specification (TS) Figures 3.6.1, 3.6.2, and 3.6.3 to extend the applicability of the current reactor pressure vessel pressure-temperature (P-T) curves through the end of Operating Cycle (OC) 16. The current P-T curves were approved for use in License Amendment 190, dated April 13, 2001, and are limited to use through the end of OC 14. The proposed change would delete the 20 and 32 Effective Full Power Year curves and replace the wording of the title blocks to allow use through the end of OC 16.

Date of issuance: March 28, 2003.

Effective date: As of the date of issuance, and shall be implemented within 60 days.

Amendment No.: 197.

Facility Operating License No. DPR-35: This amendment revised the TS.

Date of initial notice in Federal Register: February 18, 2003 (68 FR 7816).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 28, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-382, Waterford Steam Electric Station, Unit 3, St. Charles Parish, Louisiana

Date of amendment request: August 19, 2002, as supplemented by letter dated December 19, 2002.

Brief description of amendment: The amendment revises the Technical Specifications by: (1) Modifying the wording of the current Surveillance Requirement (SR) 4.0.1 and SR 4.0.3 to be consistent with NUREG-1431, Revision 2, Improved Standard Technical Specifications (ISTS) wording for SR 3.0.1 and SR 3.0.3; and (2) modifying the ISTS wording, adopted in Item (1), above, for SR 4.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance. The delay period is extended from the current limit of up to 24 hours " * * * when the allowable outage time limits of the ACTION requirements are less than 24 hours" to " * * * up to 24 hours or up to the limit of the specified surveillance interval, whichever is greater." In addition, the following

requirement is added to SR 4.0.3: "A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed."

Date of issuance: March 21, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 187.

Facility Operating License No. NPF-38: The amendment revised the Technical Specifications and Surveillance Requirements.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5670).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 21, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-382, Waterford Steam Electric Station, Unit 3, St. Charles Parish, Louisiana

Date of amendment request: December 20, 2002.

Brief description of amendment: This amendment approves several administrative changes to the Waterford Steam Electric Station, Unit 3 Technical Specifications (TSs) to revise, correct, or clarify certain titles, page numbers, and heading information. It also revises personnel and committee titles that have been changed, revises administrative reporting requirements to conform to 10 CFR 50.4, and deletes redundant or unnecessary requirements from TSs 5.4, 6.6, and 6.7.

Date of issuance: April 3, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 188.

Facility Operating License No. NPF-38: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5673).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 3, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Date of application for amendments: August 16, 2002.

Brief description of amendments: The amendments modify the Unit 3 allowable value Technical Specification, and the Units 2 and 3 surveillance requirements Technical Specification

for the reactor protection system scram discharge volume water level-high function.

Date of issuance: April 3, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment Nos.: 198/191.

Facility Operating License Nos. DPR-19 and DPR-25: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68737).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 3, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-373 and 50-374, LaSalle County Station, Units 1 and 2, LaSalle County, Illinois

Date of application for amendments: November 27, 2002.

Brief description of amendments: These amendments delete Technical Specification (TS) 5.5.3, "Post Accident Sampling," and thereby eliminate the requirements to have and maintain the post accident sampling system at the LaSalle County Station, Units 1 and 2. The amendments also address related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

Date of issuance: March 21, 2003.

Effective date: As of the date of issuance and shall be implemented within 180 days.

Amendment Nos.: 158/144.

Facility Operating License Nos. NPF-11 and NPF-18: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: January 21, 2003 (68 FR 2802).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated March 21, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-254 and 50-265, Quad Cities Nuclear Power Station, Units 1 and 2, Rock Island County, Illinois

Date of application for amendments: August 22, 2002.

Brief description of amendments: The amendments modify the required surveillance interval from monthly to quarterly for calibration of the trip units associated with the instrumentation channels of the Anticipated Transient Without Scram-Recirculation Pump Trip system.

Date of issuance: April 1, 2003.