

Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment Nos.: 213 and 207.

Facility Operating License Nos. DPR-29 and DPR-30: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: October 1, 2002 (67 FR 61682). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 1, 2003.

No significant hazards consideration comments received: No.

Indiana Michigan Power Company, Docket No. 50-316, Donald C. Cook Nuclear Plant, Unit 2, Berrien County, Michigan

Date of application for amendment: October 16, 2002, as supplemented January 28, 2003.

Brief description of amendment: The amendment would revise the Technical Specification values for the 4 kilovolt degraded-voltage and loss-of-voltage relays.

Date of issuance: March 26, 2003.

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment No.: 256.

Facility Operating License No. DPR-74: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68739).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 26, 2003.

No significant hazards consideration comments received: No.

Nine Mile Point Nuclear Station, LLC, Docket No. 50-220, Nine Mile Point Nuclear Station, Unit No. 1, Oswego County, New York

Date of application for amendment: December 19, 2002.

Brief description of amendment: The amendment revised the Technical Specifications to add the definition of shutdown margin (SDM), incorporate new, more restrictive SDM limits, add the associated limiting condition for operation actions and completion times for each applicable operating condition if the SDM is not met, and add surveillance requirements for verifying SDM.

Date of issuance: March 27, 2003.

Effective date: March 27, 2003.

Amendment No.: 180.

Facility Operating License No. DPR-63: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 21, 2003 (68 FR 2806).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 27, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-331, Duane Arnold Energy Center, Linn County, Iowa

Date of application for amendment: March 29, 2002, as supplemented by letter dated January 24, 2003.

Brief description of amendment: The amendment changes the surveillance requirement of TS 5.5.12, "Primary Containment Leakage Rate Testing Program," to allow a one-time 5-year extension to the 10-year interval for performing the next Type A containment integrated leakage rate test (ILRT). The change allows ILRT testing within 15 years from the last ILRT, which was performed in September 1993.

Date of issuance: March 21, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 249.

Facility Operating License No. DPR 49: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: April 30, 2002 (67 FR 21291). The supplemental letter contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 21, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota

Date of application for amendment: April 22, 2002, as supplemented October 25, 2002, January 23, and February 12, 2003.

Brief description of amendment: The amendment changes TS Surveillance Requirement 4.7.A.2.b, "Primary Containment Integrity," to allow a one-time, 5-year extension to the 10-year interval for performing the next Type A containment integrated leakage rate test

(ILRT). The change allows ILRT testing within 15 years from the last ILRT, which was performed in March 1993.

Date of issuance: March 31, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 134.

Facility Operating License No. DPR-22: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 3, 2002 (67 FR 56324).

The October 25, 2002, January 23, and February 12, 2003, supplements provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the Nuclear Regulatory Commission staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 31, 2003.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey

Date of application for amendment: July 25, 2002, as supplemented on October 21, 2002.

Brief description of amendment: The amendment would modify Technical Specification (TS) requirements for missed surveillance tests in TS 4.0.3 using the Consolidated Line Item Improvement Program, modify TS 4.0.1 to be consistent with the Standard Technical Specifications (STS), and incorporate a TS Bases Control Program in Section 6.0 in accordance with the STS.

Date of issuance: March 31, 2003.

Effective date: March 31, 2003.

Amendment No.: 145.

Facility Operating License No. NPF-57: This amendment revised the Technical Specifications.

Date of initial notice in Federal Register: December 10, 2002 (67 FR 75883)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 31, 2003.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-348 and 50-364, Joseph M. Farley Nuclear Plant, Units 1 and 2, Houston County, Alabama

Date of amendments request: April 4, 2002, as supplemented by letter dated January 9, 2003.

Brief Description of amendments: The amendments revise Technical