

TABLE 3 OF SUBPART YYYY OF PART 63.—REQUIREMENTS FOR PERFORMANCE TESTS AND INITIAL COMPLIANCE DEMONSTRATIONS—Continued

For each stationary combustion turbine complying with . . .	You must . . .	Using . . .	According to the following requirements . . .
2. The emission limitation for formaldehyde emission concentration.	<p>a. Demonstrate formaldehyde emissions are 43 ppbvd or less by a performance test and.</p> <p>b. Select the sampling port location and the number of traverse points and.</p> <p>c. Determine the O₂ concentration at the sampling port location.</p>	<p>i. Test Method 320 of 40 CFR part 63, appendix A; or EPA SW-846 Method 0011; or California Environmental Protection Agency, Air Resources Board, Method 430* formaldehyde and acetaldehyde in emissions from stationary sources, adopted Sept 12, 1989, amended December 13, 1991 (ARB Method 430)*; or if your affected source fires natural gas, Test Method 323 of 40 CFR part 63, appendix A; or other methods approved by the Administrator.</p> <p>i. Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i).</p> <p>i. Method 3A or 3B of 40 CFR part 60, appendix A.</p>	<p>(1) Formaldehyde concentration must be corrected to 15 percent O₂, dry basis. Results of this test consist of the average of the three 1 hour runs.</p> <p>(1) If using an air pollution control device, the sampling site must be located at the outlet of the air pollution control device.</p> <p>(1) Measurements to determine O₂ concentration must be made at the same time as the performance test.</p>

* You may obtain a copy of ARB Method 430 from the California Environmental Protection Agency, Air Resources Board, 2020 L Street, Sacramento, CA 95812, or you may download a copy of ARB Method 430 from ARB's web site (<http://www.arb.ca.gov/testmeth/vol3/vol3.htm>).

As stated in §§ 63.6110 and 63.6130, you must comply with the following requirements to demonstrate initial compliance with emission limitations:

TABLE 4 TO SUBPART YYYY OF PART 63.—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS

For the . . .	You have demonstrated initial compliance if . . .
1. Emission limitation for CO reduction	The average reduction of CO emissions is at least 95 percent, dry basis.
2. Emission limitation for formaldehyde	The average formaldehyde concentration is 43 ppbvd or less at 15 percent O ₂ .

As stated in §§ 63.6135 and 63.6140, you must comply with the following requirements to demonstrate continuing compliance with emissions limitations:

TABLE 5 OF SUBPART YYYY OF PART 63.—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS

For the . . .	You must demonstrate continuous compliance by . . .
1. Emission limitation for CO reduction	<p>a. Collecting the CEMS data according to § 63.6125(a), reducing the measurements to 1-hour averages, calculating the percent reduction in CO emissions according to § 63.6120; and</p> <p>b. Demonstrating a reduction in CO of 95 percent or more over each 4-hour averaging period; and</p> <p>c. Applying 40 CFR part 60 appendix F, procedure 1.</p>

As stated in §§ 63.6135 and 63.6140, you must comply with the following requirements to demonstrate continuing compliance with operating limitations:

TABLE 6 OF SUBPART YYYY OF PART 63.—CONTINUOUS COMPLIANCE WITH OPERATING LIMITATIONS

For the emission limitation . . .	For the operating limitation . . .	You must demonstrate continuous compliance by . . .
For formaldehyde	To comply with operating limitations approved by the Administrator.	Collect the data according to § 63.6120(g) and maintain the operating parameters within the operating limits.

As stated in §§ 63.6145 and 63.6150, you must comply with the following requirements for reports: