

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 4, 2003.

No significant hazards consideration comments received: No.

*FirstEnergy Nuclear Operating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit 1, Ottawa County, Ohio*

*Date of application for amendment:* June 4, 2002, as supplemented by letter dated February 19, 2003.

*Brief description of amendment:* This amendment revises Technical Specification (TS) Surveillance Requirement (SR) 4.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance to "\* \* \* up to 24 hours or up to the limit of the specified frequency, whichever is greater." In addition, the amendment adds requirements to SR 4.0.3 to perform a risk evaluation for any Surveillance delayed greater than 24 hours and manage the risk impact, and specifies actions to be taken when a delayed surveillance is not performed or not met. The amendment is consistent with TS Task Force traveler TSTF-358, which has been approved by the Nuclear Regulatory Commission for incorporation into standard technical specifications in NUREG-1430. The TS Bases will be revised under the licensee's existing TS Bases control program to be consistent with the bases for TSTF-358.

*Date of issuance:* April 11, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 120 days.

*Amendment No.:* 254.

*Facility Operating License No. NPF-3:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 7, 2003 (68 FR 804).

The supplemental information contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 11, 2003.

No significant hazards consideration comments received: No.

*FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit 1, Lake County, Ohio*

*Date of application for amendment:* June 10, 2002.

*Brief description of amendment:* This amendment revises Surveillance

Requirement (SR) 3.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance. The delay period is extended from the current limit of "\* \* \* up to 24 hours or up to the limit of the specified Frequency, whichever is less" to "\* \* \* up to 24 hours or up to the limit of the specified Frequency, whichever is greater." In addition, the following requirement is added to SR 3.0.3: "A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed."

*Date of issuance:* April 17, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 90 days.

*Amendment No.:* 125.

*Facility Operating License No. NPF-58:* This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 18, 2003 (68 FR 12954).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 17, 2003.

No significant hazards consideration comments received: No.

*FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit 1, Lake County, Ohio*

*Date of application for amendment:* March 14, 2002, as supplemented by letter dated January 20, 2003.

*Brief description of amendment:* This amendment revised technical specification (TS) 5.5.12, "Primary Containment Leakage Rate Testing Program," to allow a one-time exception to Nuclear Energy Institute 94-01, "Industry Guidance for Implementing Performance-Based Option of 10 CFR part 50 Appendix J," that extends the test interval of the containment integrated leak rate test from 10 to 15 years.

*Date of issuance:* April 8, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 90 days.

*Amendment No.:* 126.

*Facility Operating License No. NPF-58:* This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5676).

The supplemental information contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 8, 2003.

No significant hazards consideration comments received: No.

*Florida Power and Light Company, et al., Docket Nos. 50-335 and 50-389, St. Lucie Plant, Unit Nos. 1 and 2, St. Lucie County, Florida*

*Date of application for amendments:* August 15, 2002, as supplemented December 13, 2002.

*Brief description of amendments:* The amendments revise Technical Specifications Section 6.8.4.h, Containment Leakage Rate Testing Program, to allow a one-time 5-year extension to the current 10-year test interval for the containment integrated leak rate test (ILRT). The changes were submitted on a risk-informed basis as described in Regulatory Guide 1.174, An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis. The risk-informed analysis supporting the changes indicates that the increase in risk from extending the ILRT test interval from 10 to 15 years is insignificant.

*Date of Issuance:* April 10, 2003.

*Effective Date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment Nos.:* 187 & 130.

*Facility Operating License Nos. DPR-67 and NPF-16:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* September 17, 2002 (67 FR 58647).

The supplement dated December 13, 2002, provided clarifying information that did not change the scope of the August 15, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 10, 2003.

No significant hazards consideration comments received: No.

*PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey*

*Date of application for amendment:* June 28, 2002, as supplemented December 18, 2002, January 18, 2003, and February 25, 2003.

*Brief description of amendment:* The amendment relaxes certain Technical Specifications (TSs) requirements for containment isolation and removes references to the Filtration Recirculation and Ventilation System charcoal filters.

*Date of issuance:* April 15, 2003.