

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment No.:* 154.

*Facility Operating License No. NPF-43:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* November 26, 2002 (67 FR 70764).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 28, 2003.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, Docket Nos. 50-269, 50-270, and 50-287, Oconee Nuclear Station, Units 1, 2, and 3, Oconee County, South Carolina*

*Date of application of amendments:* December 4, 2002.

*Brief description of amendments:* The amendments revised the Technical Specification 3.7.6 to require a minimum combined inventory of 155,000 gallons and remove the Condensate Storage Tank as a source of the combined inventory.

*Date of Issuance:* April 30, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 330, 330 & 331.

*Renewed Facility Operating License Nos. DPR-38, DPR-47, and DPR-55:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 31, 2003 (68 FR 2801).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 30, 2003.

*No significant hazards consideration comments received:* No

*Entergy Nuclear Operations, Inc., Docket No. 50-333, James A. FitzPatrick Nuclear Power Plant, Oswego County, New York*

*Date of application for amendment:* December 6, 2002.

*Brief description of amendment:* The amendment increased the surveillance interval of the local power range monitor calibrations from 1000 megawatt-days/ton to 200 megawatt-days/ton.

*Date of issuance:* May 1, 2003.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment No.:* 277.

*Facility Operating License No. DPR-59:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5674).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 1, 2003.

*No significant hazards consideration comments received:* No.

*Entergy Nuclear Operations, Inc., Docket No. 50-293, Pilgrim Nuclear Power Station, Plymouth County, Massachusetts*

*Date of application for amendment:* August 16, 2002, as supplemented on March 26, April 16, and April 19, 2003.

*Brief description of amendment:* The amendment modified Technical Specification (TS) 3/4.10.A, "Refueling Interlocks," and TS 3/4.10.D, "Multiple Control Rod Removal," to provide an alternative required action if the refueling interlocks became inoperable during fuel movements in the reactor vessel. The amendment allowed fuel movements to continue in the reactor vessel should the refueling equipment interlocks become inoperable.

*Date of issuance:* April 21, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 60 days.

*Amendment No.:* 199.

*Facility Operating License No. DPR-35:* Amendment revised the TSs.

*Date of initial notice in Federal Register:* December 10, 2002 (67 FR 75872).

The March 26, April 16, and April 19, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 21, 2003.

*No significant hazards consideration comments received:* No.

*Entergy Nuclear Operations, Inc., Docket No. 50-293, Pilgrim Nuclear Power Station, Plymouth County, Massachusetts*

*Date of application for amendment:* January 23, 2003, as supplemented February 24, and April 17, 2003.

*Brief description of amendment:* This amendment modifies the Pilgrim Nuclear Power Station Technical Specification (TS) requirements for the Emergency Core Cooling System (ECCS) during shutdown conditions. The amendment changes the Core Spray and Low Pressure Coolant Injection System's TS requirements to be applicable during the Run, Startup, and Hot Shutdown Modes. The amendment also modifies the High Drywell Pressure Instrumentation TSs to require the

instrumentation to be Operable during the Run, Startup and Hot Shutdown Modes. Unnecessary TS requirements are removed based on the plant's operating Mode. Other changes are administrative in nature.

*Date of issuance:* April 22, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 60 days.

*Amendment No.:* 200.

*Facility Operating License No. DPR-35:* Amendment revised the TSs.

*Date of initial notice in Federal Register:* March 18, 2003 (68 FR 12952).

The supplements dated February 24, and April 17, 2003, provided additional information that clarified the application, and did not expand the scope of the application or change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 22, 2003.

*No significant hazards consideration comments received:* No.

*Entergy Operations, Inc., System Energy Resources, Inc., South Mississippi Electric Power Association, and Entergy Mississippi, Inc., Docket No. 50-416, Grand Gulf Nuclear Station, Unit 1, Claiborne County, Mississippi*

*Date of application for amendment:* September 18, 2002.

*Brief description of amendment:* The amendment revises several Technical Specifications Limiting Conditions for Operations and Administrative sections to correct or clarify certain requirements and information.

*Date of issuance:* April 23, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment No.:* 157.

*Facility Operating License No. NPF-29:* The amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* December 10, 2002 (67 FR 75871).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 23, 2003.

*No significant hazards consideration comments received:* No.

*Exelon Generation Company, LLC, Docket Nos. 50-237, Dresden Nuclear Power Station, Unit 2, Grundy County, Illinois*

*Date of application for amendment:* January 31, 2003, as supplemented March 7, 2003.

*Brief description of amendment:* The amendment revises the safety limit