

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Units 1 and 2, Berrien County, Michigan

Date of application for amendments: January 14, 2003.

Brief description of amendments: The amendments modify Technical Specification (TS) 3.7.5.1 to add an exception to Limiting Condition for Operation 3.0.4 for the control room emergency ventilation system (CREVS). This exception allows movement of irradiated fuel assemblies to begin while one of the two CREVS pressurization trains is inoperable, provided the appropriate TS action requirements are implemented. The amendments are consistent with the standard TSs for Westinghouse plants (NUREG 1431, Revision 2, "Standard Technical Specifications, Westinghouse Plants," dated April 30, 2001).

Date of issuance: April 25, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 276 and 258.

Facility Operating License Nos. DPR-58 and DPR-74: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: March 4, 2003 (68 FR 10280).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 25, 2003.

No significant hazards consideration comments received: No.

Nine Mile Point Nuclear Station, LLC, Docket No. 50-220, Nine Mile Point Nuclear Station, Unit No. 1, Oswego County, New York

Date of application for amendment: October 26, 2001, as supplemented by letters dated June 7 and November 22, 2002.

Brief description of amendment: The amendment revised Section 6.0, "Administrative Controls," of the Technical Specifications (TSs) to clarify and relocate existing requirements, make wording improvements, and make the TSs consistent with the Unit 2 TSs. The revised Section 6.0 is consistent with the "Standard Technical Specifications for General Electric plants, BWR [Boiling Water Reactor]/4" (NUREG-1433, Revision 2).

Date of issuance: April 23, 2003.

Effective date: April 23, 2003, to be implemented within 90 days of issuance.

Amendment No.: 181.

Facility Operating License No. DPR-63: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 8, 2002 (67 FR 928).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 23, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: July 26, 2002, as supplemented February 27, March 14, March 19, March 21 (2 letters), and April 3, 2003.

Brief description of amendment: The amendment revises technical specifications for use of Westinghouse 422 VANTAGE + nuclear fuel with PERFORMANCE + features.

Date of issuance: April 4, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 167.

Facility Operating License No. DPR-43: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 3, 2002 (67 FR 56322).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 4, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota

Date of application for amendment: September 19, 2002, as supplemented February 28, 2003.

Brief description of amendment: The amendment relocates TS Surveillance Requirement (SR) 4.6.B.2, "Reactor Vessel Temperature and Pressure," and the associated TS Bases to Section 4.2 of the Updated Safety Analysis Report. It also implements the Boiling Water Reactor Vessel and Internals Project reactor pressure vessel integrated surveillance program at Monticello and demonstrates compliance with the requirements of Title 10 of the Code of Federal Regulations, Part 50, Appendix H, "Reactor Vessel Material Surveillance Program Requirements."

Date of issuance: April 22, 2003

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 135.

Facility Operating License No. DPR-22: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: October 29, 2002 (67 FR 66012).

The supplement of February 28, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the Nuclear Regulatory Commission staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 22, 2003.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska

Date of amendment request: October 8, 2002, and its supplements dated December 3, 2002, and March 4, 2003.

Brief description of amendment: The amendment modifies Technical Specification 2.3.a, "Emergency Core Cooling System," to extend the allowed outage time for a single low pressure safety injection pump from the existing 24 hours to 7 days. In addition, the word "pump" has been replaced with the word "train."

Date of issuance: April 29, 2003

Effective date: April 29, 2003, and shall be implemented within 60 days from the date of issuance.

Amendment No.: 217.

Facility Operating License No. DPR-40: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68740).

The supplemental letters dated December 3, 2002, and March 4, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed or revise the proposed technical specification changes and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 29, 2003.

No significant hazards consideration comments received: No.

Saxton Nuclear Experimental Corporation (SNEC) and GPU Nuclear, Inc., Docket No. 50-146 Saxton Nuclear Experimental Facility (SNEF), Bedford County, Pennsylvania

Date of application for amendment: February 2, 2000, as supplemented on