

June 23, August 11, September 18 and December 4, 2000; January 30, February 14, March 15 and 19, June 20, July 2 and September 4, 2001; and January 11 and 24, February 4, May 22 and 28, July 11, August 20, September 17, 23, 24, and 26, October 10, and December 16, 2002.

Brief description of amendment: The amendment revises Amended Facility License No. DPR-4 for the SNEF to annotate approval of the SNEF License Termination Plan.

Date of issuance: March 28, 2003.

Effective date: Date of issuance to be implemented no later than 30 days from the date of issuance.

Amendment No.: 18.

Amended Facility License No. DPR-4: Amendment added a new license condition to require the licensees to implement and maintain in effect all provisions of the approved SNEF License Termination Plan.

Date of initial notice in Federal Register: November 29, 2000.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 28, 2003.

No significant hazards consideration comments received: No.

STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas

Date of amendments request: November 5, 2001, as supplemented by letters dated October 23, 2002, and January 15, 2003.

Brief description of amendments: The proposed amendments convert the current Technical Specification (TS) Section 6.0 of the STP, Units 1 and 2, TS to the Improved Technical Specifications based on NUREG-1431, "Standard Technical Specification for Westinghouse Plants."

Date of issuance: April 24, 2003.

Effective date: As of its date of issuance and shall be implemented within 6 months from the date of issuance.

Amendment Nos.: Unit 1-151; Unit 2-139.

Facility Operating License Nos. NPF-76 and NPF-80: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 5, 2002 (67 FR 5335).

The October 23, 2002, and January 15, 2003, supplemental letters provided clarifying information that was within the scope of the original **Federal Register** notice (67 FR 5335) and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 24, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-327, Sequoyah Nuclear Plant, Unit 1, Hamilton County, Tennessee

Date of application for amendment: February 28, 2003.

Brief description of amendment: The amendment approves the use of an alternate methodology using a through-bolted connection frame to restore the steam generator (SG) compartment roof after replacement of the SGs, and a revision of the Updated Safety Analysis Report (UFSAR) to reflect the approval of the methodology.

Date of issuance: April 25, 2003.

Effective date: As of the date of issuance, to be incorporated into the UFSAR at the time of its next update.

Amendment No.: 184.

Facility Operating License No. DPR-77: Amendment revises the UFSAR.

Date of initial notice in Federal Register: March 14, 2003 (68 FR 12382).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 25, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-327, Sequoyah Nuclear Plant (SQN), Unit 1, Hamilton County, Tennessee

Date of application for amendment: February 28, 2003.

Description of amendment: The amendment approves a revision of the SQN Updated Final Safety Analysis (UFSAR) to include a change to the methodology for connecting reinforcing steel bars during restoration of the Unit 1 concrete shield building dome as part of the steam generator replacement project. This modification to the shield building concrete dome is necessary to support removal of the original steam generators and installation of the replacement steam generators.

Date of issuance: April 24, 2003.

Effective date: As of the date of issuance to be incorporated into the UFSAR at the time of its next update.

Amendment No.: 283.

Facility Operating License No. DPR-77: Amendment revises the Operating License.

Date of initial notice in Federal Register: March 17, 2003 (68 FR 12718).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 24, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant, Unit 1, Rhea County, Tennessee

Date of application for amendment: April 8, 2003, as supplemented April 22, 2003.

Brief description of amendment: The amendment revises, for one time only, a portion of Surveillance Requirement (SR) 3.5.2.3 of the Watts Bar Technical Specifications for the emergency core cooling system (ECCS). The revision extends, until the refueling outage in the fall of 2003, the verification that the ECCS safety injection hot leg injection lines are full of water. SR 3.5.2.3 currently requires a verification frequency of 31 days.

Date of issuance: May 1, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days of issuance.

Amendment No.: 43.

Facility Operating License No. NPF-90: Amendment revises the Technical Specifications.

Public comments requested as to proposed no significant hazards consideration: Yes. (68 FR 18712 dated April 16, 2001). That notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by May 16, 2003, but indicated that if the Commission makes a final no significant hazards consideration determination, any such hearing would take place after issuance of the amendment. The April 22, 2003, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the scope of the original request.

The Commission's related evaluation of the amendments, finding of exigent circumstances, and final no significant hazards consideration determination are contained in a Safety Evaluation dated May 1, 2003.

Attorney for licensee: General Counsel, Tennessee Valley Authority, 400 West Summit Hill Drive, ET 11A, Knoxville, Tennessee 37902.

NRC Section Chief: Allen G. Howe.

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri

Date of application for amendment: October 3, 2002.

Brief description of amendment: The amendment revises Limiting Condition for Operation 3.1.8, "Physics Tests Exceptions—Mode 2," to reduce the required number of channels from four