

date of this order.³ State Commission ALJs or expert staff that participate in the fact-finding may offer written comments or conclusions that will be appended to the Commission ALJ's report.

The Commission Orders

(A) The Secretary is hereby directed to publish this order in the **Federal Register**.

(B) Entities seeking to participate in this proceeding should file notices of their intent to participate within ten days of the date of this order. However, since this proceeding will not be a formal case, we direct the ALJ to welcome late participants to the proceeding rather than holding strictly to the formal rules of participation and intervention.

(C) Pursuant to the authority contained in and subject to the jurisdiction conferred upon the Federal Energy Regulatory Commission by Section 402(a) of the Department of Energy Organization Act and by the Federal Power Act, and pursuant to the Commission's Rules of Practice and Procedure and the regulations under the Federal Power Act (18 CFR, Chapter I), and the appropriate guidelines for Alternate Dispute Resolutions, the ALJ shall conduct whatever proceedings and hearings may be appropriate to determine the facts and solutions concerning congestion on the Delmarva Peninsula, as discussed in the body of this order.

(D) A presiding administrative law judge, to be designated by the chief administrative law judge, shall convene a conference in the proceeding to be held within fifteen days of the date of this order, in a hearing room of the Federal Energy Regulatory Commission, 888 First Street, NW., Washington, DC 20426. The presiding judge is authorized to establish procedural dates and to rule on all motions (except motions to dismiss) as provided for in the Commission's Rules of Practice and Procedure.

(E) The presiding judge shall file a report within sixty days after the date of this order, as discussed in the body of this order.

(F) Any State Commission that is interested in having its ALJ participate in the case study should contact the Commission ALJ to make the appropriate arrangements.

³ The ALJ report will not be an initial decision, so we will not entertain the filing of briefs on or opposing exceptions. Further, we do not anticipate the need for cross-examination of witnesses. The Judge need not create an exhaustive record, but may work with the parties to create the record that provides a thorough picture of the facts, problems, and opportunities, and lessons to be learned.

(G) The Commission's Office of Administrative Litigation shall provide technical support to the ALJ and the parties in this proceeding.

By the Commission.

Magalie R. Salas,

Secretary.

[FR Doc. 03-12429 Filed 5-16-03; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Western Area Power Administration

Construction and Operation of the Proposed Wellton-Mohawk Generating Facility, Yuma County, AZ

AGENCY: Western Area Power Administration, DOE.

ACTION: Notice of Intent to Prepare an Environmental Impact Statement.

SUMMARY: The Western Area Power Administration (Western) intends to prepare an environmental impact statement (EIS) regarding the proposal by Dome Valley Energy Partners, LLC (Dome Valley) to construct and operate the Wellton-Mohawk Generating Facility (Facility) east of Yuma, Arizona. The EIS will also address the construction of a new natural gas pipeline and high-voltage transmission line upgrades and additions needed to support the Facility, a no-action alternative, and any action alternatives defined as a result of the EIS scoping process.

Because implementing this proposal would incorporate a major new generation resource into Western's system, Western has determined that an EIS is required. Western will hold a 30-day scoping period to ensure that interested members of the public and Federal, State, local, and tribal agencies have an opportunity to provide input on the scope and alternatives that will be addressed in the EIS. Western also will hold public open-house scoping meetings in the project area during the scoping period.

DATES: The public scoping meetings will be held on June 3, 2003, in Wellton, and June 4, 2003, in Yuma. Each meeting will be held between 6 p.m. and 9 p.m. Written comments on the scope of the EIS for the proposed Project should be received no later than 11:59 p.m. (Arizona Time) on June 30, 2003, which will be the end of the EIS scoping period. Comments on the project will be accepted throughout the National Environmental Policy Act (NEPA) process.

ADDRESSES: The Wellton scoping meeting will be held at the Wellton

Elementary School, 29126 San Jose Avenue in Wellton. The Yuma scoping meeting will be held at the Yuma Civic and Convention Center, 1440 West Desert Hills Drive in Yuma. Each facility is handicapped accessible. Comments should be addressed to Mr. John Holt, Environment Manager, Desert Southwest Customer Service Region, Western Area Power Administration, P.O. Box 6457, Phoenix, AZ 85005, fax (602) 352-2630, e-mail holt@wapa.gov. **FOR FURTHER INFORMATION CONTACT:** Mr. Mark Wieringa, NEPA Document Manager, Western Area Power Administration, P.O. Box 281213, Lakewood, CO 80228-8213, telephone (720) 962-7448, fax (720) 962-7263, e-mail wieringa@wapa.gov. For general information on the Department of Energy's NEPA review procedures or status of a NEPA review, contact Carol M. Borgstrom, Director of NEPA Policy and Compliance, EH-42, U.S. Department of Energy, 1000 Independence Avenue SW., Washington, DC 20585, telephone (202) 586-4600 or (800) 472-2756.

SUPPLEMENTARY INFORMATION: The Facility would be located adjacent to Western's existing Ligurta Substation, approximately 25 miles east of Yuma, Arizona, and nine miles west of Wellton, Arizona, just north of Interstate Highway 8. Dome Valley proposes to construct and operate a natural gas-fired combined-cycle electricity generating facility, an associated solar collection field, and ancillary facilities in unincorporated Yuma County, Arizona. The proposed Facility would be developed in two phases. The full output of the first phase would be nominally rated at 260 megawatts (MW) with about 310-MW peaking capacity. With the second phase, the Facility would be nominally rated at 520 MW with peaking capacity of about 620 MW via duct burners. Each phase would consist of one combustion turbine, one heat recovery steam generator, a steam turbine, condenser, transformer, cooling towers, tanks, sedimentation/evaporation ponds, auxiliary boilers, an emergency generator, an emergency fire pump, and associated buildings. Water for the Facility's use, including cooling, would be provided by the Wellton-Mohawk Irrigation and Drainage District (Wellton-Mohawk) via the Wellton-Mohawk Canal. Associated with the Facility would be a solar component that would convert solar energy to thermal energy for inlet air-cooling. Natural gas for the Facility would be delivered via a new natural gas pipeline that would interconnect to a proposed or existing natural gas transmission line