

amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr@nrc.gov.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 1, 2002, as supplemented on October 18, 2002, and April 17, 2003.

Brief description of amendment: The amendment revises Technical Specification (TS) 3.7.1.1, "Plant Systems: Turbine Cycle Safety Valves," to reflect results of a reanalysis of overpressurization events to allow plant operation, at corresponding reduced power levels, with up to four main steam safety valves in each main steam line inoperable.

Date of issuance: May 7, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment No.: 275.

Facility Operating License No. DPR-65: This amendment revised the TSs.

Date of initial notice in Federal Register: September 17, 2002 (67 FR 58638). The supplements dated October 18, 2002, and April 17, 2003, provided additional information which clarified the application, did not expand the scope of the application as originally

noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 7, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: September 30, 2002, as supplemented by letters dated October 17, 2002 and April 2, 2003.

Brief description of amendments: The amendments revise the Technical Specification to: (1) Modify the Surveillance Requirement to be consistent with the design of the reactor building access openings, (2) modify the frequency of the Surveillance Requirement for visual inspections for the exposed interior and exterior surface of the reactor building, and (3) modify the administrative controls for the containment leakage rate testing program.

Date of issuance: May 8, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 212/193.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68733). The supplement dated October 17, 2002, and April 12, 2003, provided clarifying information that did not change the scope of the September 30, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 8, 2003.

No significant hazards consideration comments received: No.

Energy Northwest, Docket No. 50-397, Columbia Generating Station, Benton County, Washington

Date of application for amendment: September 3, 2002, as supplemented by letters dated November 27, 2002, and April 17, 2003.

Brief description of amendment: The amendment allows the addition of depleted uranium to the fuel assembly composition described in Technical Specification (TS) 4.2.1. The amendment also revises TS 5.6.5.b to incorporate the references to the analytical methods to be used to

determine core operating limits and removes those references that will no longer be used. The amendment also allows the format for those document references to be revised as described in the staff-approved Industry/TSTF Standard Technical Specification Change Traveler, TSTF-363, "Revise Topical Report References in ITS 5.6.5, COLR."

Date of issuance: May 12, 2003.

Effective date: May 12, 2003, and shall be implemented within 30 days from the date of issuance.

Amendment No.: 185.

Facility Operating License No. NPF-21: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: October 15, 2002 (67 FR 63693). The November 27, 2002, and April 17, 2003, supplemental letters provided additional clarifying information, did not change the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 12, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-286, Indian Point Nuclear Generating Unit No. 3, Westchester County, New York

Date of application for amendment: June 26, 2002, as supplemented on March 12, 2003.

Brief description of amendment: The amendment revises Technical Specification 5.6.5.b, "Core Operating Limits Report (COLR)," to incorporate the reference to Westinghouse Topical Report WCAP-12945-P-A, "Code Qualification Document for Best Estimate Loss-of-Coolant Analysis," dated March 1998. The amendment allows the use of the analytical methodology to determine the core operating limits.

Date of issuance: May 6, 2003.

Effective date: May 6, 2003.

Amendment No.: 217.

Facility Operating License No. DPR-64: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 6, 2002 (68 FR 50952). The March 12 letter provided clarifying information that did not expand the scope of the **Federal Register** notice or change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is