

Effective date: As of the date of issuance and shall be implemented within 120 days from the date of issuance.

Amendment Nos.: 276 and 215.

Facility Operating License Nos. DPR-65 and NPF-49: These amendments revised the TSs.

Date of initial notice in Federal Register: July 9, 2002 (67 FR 45562). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 15, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-269, 50-270, and 50-287, Oconee Nuclear Station, Units 1, 2, and 3, Oconee County, South Carolina

Date of application for amendments: February 17, 2003.

Brief description of amendments: The amendments revised the Technical Specifications Surveillance Requirement 3.10.1.9 to increase the loading requirements for the Standby Shutdown Facility Diesel Generator from ≥ 3000 kW to ≥ 3280 kW.

Date of Issuance: May 19, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment Nos.: 331, 331, and 332.

Renewed Facility Operating License Nos. DPR-38, DPR-47, and DPR-55: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 1, 2003 (68 FR 15759). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 19, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-333, James A. FitzPatrick Nuclear Power Plant, Oswego County, New York

Date of application for amendment: February 27, 2003.

Brief description of amendment: The amendment deletes Technical Specification 5.5.3, "Post Accident Sampling," and thereby eliminates the requirements to have and maintain the post accident sampling system for the James A. FitzPatrick Nuclear Power Plant.

Date of issuance: May 16, 2003.

Effective date: As of the date of issuance to be implemented within 60 days.

Amendment No.: 278.

Facility Operating License No. DPR-59: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: April 15, 2003 (68 FR 18276). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 16, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-247, Indian Point Nuclear Generating Unit No. 2, Westchester County, New York

Date of application for amendment: December 12, 2002, as supplemented on April 3, 2003 and May 2, 2003.

Brief description of amendment: The amendment revises the Facility Operating License and the Technical Specifications (TSs) to increase the licensed core thermal power level to 3114.4 megawatts (MWt), which is a 1.4% increase above the currently authorized power level of 3071.4 MWt. The power uprate is based on the improvement in the core power uncertainty allowance originally required for the emergency core cooling system (ECCS) evaluations performed in accordance with Appendix K, "ECCS Evaluation Models," to Part 50 of Title 10 of the Code of Federal Regulations. Specifically, the reduced uncertainty is obtained by using a more accurate measurement of feedwater flow. In addition, changes were made to TS Sections 1.1, 2.1, 2.3, 3.1, 3.4, 6.9, and the applicable TS Bases to account for the change in power level.

Date of issuance: May 22, 2003.

Effective date: May 22, 2003.

Amendment No.: 237.

Facility Operating License No. DPR-26: Amendment revised the Technical Specifications and License.

Date of initial notice in Federal Register: January 7, 2003 (68 FR 00801). The April 3 and May 3, 2003, letters provided clarifying information that did not enlarge the scope of the original **Federal Register** notice or change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 22, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-368, Arkansas Nuclear One, Unit No. 2, Pope County, Arkansas

Date of application for amendment: November 22, 2002, as supplemented by letter dated March 13, 2003.

Brief description of amendment: The amendment allows for a one-time change to revise the steam generator in-service inspection frequency

requirements in Technical Specification 4.4.5.3.a to allow a 40-month inspection interval after one inspection, rather than after two consecutive inspections, based on the results falling into the C-1 classification.

Date of issuance: May 28, 2003.

Effective date: As of the date of issuance to be implemented within 60 days from the date of issuance.

Amendment No.: 247.

Facility Operating License No. NPF-6: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: December 24, 2002 (67 FR 78520). The March 13, 2003, supplemental letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 28, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. STN 50-454 and STN 50-455, Byron Station, Unit Nos. 1 and 2, Ogle County, Illinois; Docket Nos. STN 50-456 and STN 50-457, Braidwood Station, Unit Nos. 1 and 2, Will County, Illinois

Date of application for amendments: December 12, 2002.

Brief description of amendments: The amendments would add a new Surveillance Requirement to Technical Specification Section 3.7.5, "Auxiliary Feedwater (AF) System," which requires operation of the diesel-driven AF pump on a monthly frequency (*i.e.*, once every 31 days) for greater than or equal to 15 minutes.

Date of issuance: May 22, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 132/127.

Facility Operating License Nos. NPF-37, NPF-66, NPF-72 and NPF-77: The amendments revised the Technical Specifications 3.7.5.

Date of initial notice in Federal Register: February 18, 2003 (68 FR 7817). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 28, 2003.

No significant hazards consideration comments received: No.