

*Exelon Generation Company, LLC, and PSEG Nuclear LLC, Docket Nos. 50–277 and 50–278, Peach Bottom Atomic Power Station, Units 2 and 3, York County, Pennsylvania*

*Date of application for amendments:* November 27, 2002.

*Brief description of amendments:* These amendments deleted TS 5.5.3, “Post Accident Sampling,” and thereby eliminated the requirements to have and maintain the post accident sampling system for Peach Bottom Atomic Power Station, Units 2 and 3.

*Date of issuance:* May 22, 2003.

*Effective date:* As of the date of issuance, to be implemented within 180 days.

*Amendments Nos.:* 248 and 251.

*Renewed Facility Operating License Nos. DPR–44 and DPR–56:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 21, 2003 (68 FR 2802). The Commission’s related evaluation of the amendments is contained in a Safety Evaluation dated May 22, 2003.

*No significant hazards consideration comments received:* No.

*Indiana Michigan Power Company, Docket Nos. 50–315 and 50–316, Donald C. Cook Nuclear Plant, Units 1 and 2, Berrien County, Michigan*

*Date of application for amendments:* August 30, 2002 as supplemented by letters dated February 27, April 7, April 29, and May 2, 2003.

*Brief description of amendments:* The amendments revise the reactor trip system and engineered safety features actuation system surveillance requirements, increasing selected surveillance intervals for analog channels, logic cabinets, and reactor trip breakers. Additionally, the amendments revise the reactor trip system and engineered safety features actuation system surveillance requirements, increasing the completion time and bypass time for the reactor trip breakers.

*Date of issuance:* May 23, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days.

*Amendment Nos.:* 277 and 260.

*Facility Operating License Nos. DPR–58 and DPR–74:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* October 15, 2002 (67 FR 63695). The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the

original **Federal Register** notice. The Commission’s related evaluation of the amendments is contained in a Safety Evaluation dated May 23, 2003.

*No significant hazards consideration comments received:* No.

*Nuclear Management Company, LLC, Docket No. 50–331, Duane Arnold Energy Center, Linn County, Iowa*

*Date of application for amendment:* March 11, 2003.

*Brief description of amendment:* The amendment changes the operating license by adding a paragraph authorizing the licensee to revise the updated final safety analysis report by deleting the notation that the Nuclear Regulatory Commission does not endorse the reactor building crane as single-failure-proof.

*Date of issuance:* May 16, 2003.

*Effective date:* As of the date of issuance and shall be implemented no later than the update of the final safety analysis report to be submitted in accordance with 10 CFR 50.71(e).

*Amendment No.:* 251.

*Facility Operating License No. DPR–49:* The amendment revised the Facility Operating License.

*Date of initial notice in Federal Register:* April 15, 2003 (68 FR 18278). The Commission’s related evaluation of the amendment is contained in a Safety Evaluation dated May 16, 2003.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket Nos. 50–327 and 50–328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendments:* July 10, 2002, as supplemented May 9, 2003.

*Brief description of amendments:* The amendments change the Sequoyah Nuclear Plant (SQN) Technical Specifications (TSs) by modifying the requirements applicable when actions or other requirements direct suspension of activities that involve a positive reactivity change for the SQN TSs. The proposed change will remove the requirement to not make positive reactivity changes during certain conditions. The changes will permit limited positive reactivity changes that are necessitated by plant operations. These changes will limit the amount of reactivity changes to those that will continue to assure appropriate reactivity limits are met, either shutdown margin or refueling boron concentration, as appropriate.

*Date of issuance:* May 22, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days of issuance.

*Amendment Nos.:* 285 and 274.

*Facility Operating License Nos. DPR–77 and DPR–79:* Amendments revise the Technical Specifications.

*Date of initial notice in Federal Register:* August 6, 2002 (67 FR 50961). The supplemental letters provided clarifying information that was within the scope of the initial notice and did not change the initial proposed no significant hazards consideration determination. The Commission’s related evaluation of the amendment is contained in a Safety Evaluation dated May 22, 2003.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket No. 50–327, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendment:* November 15, 2002, as supplemented February 28, 2003, March 14, 2003, and April 25, 2003.

*Brief description of amendment:* The Amendments revise the Technical Specification (TS) 3.7.1.3, “Condensate Storage Water,” Limiting Condition for Operation by increasing the required minimum amount of stored water from 190,000 gallons to 240,000 gallons. This change is being made to support the replacement steam generator requirements.

*Date of issuance:* May 27, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days of issuance.

*Amendment Nos.:* 286 and 275.

*Facility Operating License No. DPR–77 and DPR–79:* Amendments revise the TSs.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5682). The supplemental letters provided clarifying information that was within the scope of the initial notice and did not change the initial proposed no significant hazards consideration determination. The Commission’s related evaluation of the amendment is contained in a Safety Evaluation dated May 27, 2003.

*No significant hazards consideration comments received:* No.

*STP Nuclear Operating Company, Docket Nos. 50–498 and 50–499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendments request:* August 19, 2002.

*Brief description of amendments:* The amendment revised Technical Specification Section 3/4.3.2, “Engineered Safety Features Actuation System Instrumentation,” to extend the interval between slave relay tests.