

(MCPRSL)" to support operating during Cycle 17. Cycle 17 is the first cycle of operation with a mixed core of ABB/CE/Westinghouse SVEA-96 fuel and Framatome ANP Atrium™-10 reload fuel. The amendment also revises Surveillance Requirement (SR) 3.3.1.3.2—the low power range monitor (LPRM) calibration frequency specified in the TS for the oscillation power range monitor. This change corrects an inconsistency between the LPRM calibration frequency specified in SR 3.3.1.3.2 and SR 3.3.1.1.7, "Reactor Protection System (RPS) Instrumentation."

Date of issuance: June 2, 2003.

Effective date: June 2, 2003, and shall be implemented before the plant restarts after completion of Refueling Outage 16.

Amendment No.: 186.

Facility Operating License No. NPF-21: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: February 18, 2003 (68 FR 7815).

The April 28, 2003, supplemental letter provided additional clarifying information, did not change the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 2, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc., Docket No. 50-271, Vermont Yankee Nuclear Power Station, Vernon, Vermont

Date of application for amendment: October 4, 2002.

Brief description of amendment: Change the Technical Specifications (TSs) by extending the primary containment integrated leak rate testing interval from 10 years to no longer than approximately 10.6 years, on a one-time basis.

Date of issuance: June 2, 2003.

Effective date: As of the date of issuance, and shall be implemented within 60 days.

Amendment No.: 215.

Facility Operating License No. DPR-28: Amendment revised the TSs.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68736).

The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated June 2, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: December 23, 2002, as supplemented January 24 and April 21, 2003.

Description of amendment request: The amendment relocates, intact, Technical Specification (TS) 6.2.3, "Independent Technical Reviews;" TS 6.4, "Review and Audit;" TS 6.7.2 through 6.7.5 (specific descriptions of the procedure review and approval process); and TS 6.9, "Records Retention" to the Operational Quality Assurance Program. The amendment also changes the title of the senior onsite official from "Executive Vice President and Chief Nuclear Officer" to "Site Vice President," revises the 10 CFR 20 references in the TSs to bring them into consistency with 10 CFR 20, and makes other minor editorial changes.

Date of issuance: June 6, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 88.

Facility Operating License No. NPF-86: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: February 18, 2003 (68 FR 7817).

The April 21, 2003, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expanded the application beyond the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 6, 2003.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska

Date of amendment request: July 10, 2002, as supplemented by letter dated April 16, 2003.

Brief description of amendment: The amendment replaces the fire protection requirements contained in Facility Operating License (FOL) Section 2.C.(4) with the standard fire protection FOL condition recommended by Generic Letter 86-10, Section F, adapted to Cooper Nuclear Station.

Date of issuance: June 5, 2003.

Effective date: June 5, 2003.

Amendment No.: 199.

Facility Operating License No. DPR-46: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 7, 2003 (68 FR 808).

The supplement dated April 16, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 5, 2003.

No significant hazards consideration comments received: No.

Nine Mile Point Nuclear Station, LLC, Docket No. 50-220, Nine Mile Point Nuclear Station, Unit No. 1, Oswego County, New York

Date of application for amendment: October 7, 2002, as supplemented by letter dated March 24, 2003.

Brief description of amendment: The amendment (1) adds a new Surveillance Requirement (SR) 4.0.3 to extend the delay period, up to 24 hours or up to the limit of the specified frequency, whichever is greater, before entering a Limiting Condition for Operation following a missed surveillance; (2) adds a new SR 4.0.1 to define general conditions for use of SRs; and (3) makes various editorial and administrative changes.

Date of issuance: June 3, 2003.

Effective date: June 3, 2003, to be implemented within 60 days of issuance.

Amendment No.: 182.

Facility Operating License No. DPR-63: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68739) and April 29, 2003 (68 FR 22748).

The supplement expanded the scope of the application, and was addressed by the second notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 3, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: June 11, 2002.

Brief description of amendments: These amendments revise Technical Specification 3.1.8, "Physics Tests Exceptions—Mode 2," to correct an error in the numbering of a function. Specifically, the reference in Limiting Condition for Operation 3.1.8 to Function 17.d has been changed to Function 17.e.