

*Date of issuance:* June 3, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days.

*Amendment Nos.:* 208 & 213.

*Facility Operating License Nos. DPR-24 and DPR-27:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* September 3, 2002 (67 FR 56325).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 3, 2003.

*No significant hazards consideration comments received:* No.

*Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California*

*Date of application for amendments:* February 6, 2003.

*Brief description of amendments:* The amendments revise Surveillance Requirements (SRs) 3.3.1.2 and 3.3.1.3 of the Technical Specifications on the reactor trip system instrumentation. The proposed changes to SR 3.3.1.2 move Note 1 to the body of the SR, replace the reference to nuclear instrumentation system channel output by a reference to power range channel output, and delete the reference to the absolute difference. The change to SR 3.3.1.3 is editorial.

*Date of issuance:* June 2, 2003.

*Effective date:* June 2, 2003, and shall be implemented within 60 days of the date of issuance.

*Amendment Nos.:* Unit 1-157; Unit 2-157.

*Facility Operating License Nos. DPR-80 and DPR-82:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 15, 2003 (68 FR 18282).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 2, 2003.

*No significant hazards consideration comments received:* No.

*Pacific Gas and Electric Company, Docket No. 50-323, Diablo Canyon Nuclear Power Plant, Unit No. 2, San Luis Obispo County, California*

*Date of application for amendments:* March 3, 2003, and its supplement dated March 5, 2003.

*Brief description of amendments:* The amendment authorizes revisions to the Final Safety Analysis Report (FSAR) Update to incorporate the NRC approval of a probability of detection of 1.0 to one bobbin indication, contained in Diablo Canyon Nuclear Power Plant (DCPP) Unit 2 steam generator 4 tube at row 44, column 45 at the second tube support

plate on the hot leg side, for the beginning of cycle voltage distribution for the DCPP Unit 2 Cycle 12 operational assessment. In a **Federal Register** notice dated April 15, 2003 (68 FR 18284), the NRC described the amendment request as follows:

The proposed license amendment would revise Technical Specification (TS) 5.5.9, "Steam Generator Tube Surveillance Program," and TS 5.6.10, "Steam Generator Tube Inspection Report," for Diablo Canyon Power Plant (DCPP) Unit 2, to apply a probability of detection (POD) of 1.0 to the bobbin indication in the steam generator (SG) 4 tube at row 44, column 45 at the second tube support plate (TSP) on the hot leg side (R44C45-2H) for the beginning of cycle (BOC) voltage distribution for the DCPP Unit 2 BOC Cycle 12 operational assessment.

The change from a TS to an FSAR revision resulted from the March 5, 2003, supplement and is not substantial in that the technical issues and no significant hazards consideration determination remain the same.

*Date of issuance:* June 3, 2003.

*Effective date:* June 3, 2003, and shall be implemented within 30 days of the date of issuance. The implementation of the amendment includes the incorporation into the FSAR Update the changes discussed above, as described in the licensee's application dated March 3, 2003, its supplement dated March 5, 2003, and evaluated in the staff's safety evaluation attached to the amendment.

*Amendment No.:* 158.

*Facility Operating License No. DPR-82:* The amendment authorized revision of the FSAR Update.

*Date of initial notice in Federal Register:* April 15, 2003 (68 FR 18284).

The March 5, 2003, supplemental letter provided additional clarifying information, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 3, 2003.

*No significant hazards consideration comments received:* No.

*PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania*

*Date of application for amendments:* October 31, 2002.

*Brief description of amendments:* These amendments revised the Technical Specifications, Section 3.7.6, "Main Turbine Bypass System," to change the requirement for operability of the main turbine bypass system

bypass valves. Specifically, Surveillance Requirement 3.7.6 would be revised to test only each required turbine bypass valve every 31 days.

*Date of issuance:* May 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 210 and 185.

*Facility Operating License Nos. NPF-14 and NPF-22:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 24, 2002 (67 FR 78524).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 29, 2003.

*No significant hazards consideration comments received:* No.

*PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania*

*Date of application for amendments:* October 30, 2002.

*Brief description of amendments:* These amendments revise Technical Specifications Section 5.5.7, "Ventilation Filter Testing Program," to change the control room emergency outside air supply system (CREOASS) maximum allowed filter train pressure drop from <9.1 inches water gage (wg) to <7.3 inches wg.

*Date of issuance:* May 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 211 and 186.

*Facility Operating License Nos. NPF-14 and NPF-22:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 24, 2002 (67 FR 78523).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 29, 2003.

*No significant hazards consideration comments received:* No.

*PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania*

*Date of application for amendments:* March 3, 2003.

*Brief description of amendments:* The amendments delete Technical Specification (TS) 5.5.3, "Post Accident Sampling," and thereby eliminate the requirements to have and maintain the post-accident sampling systems. The amendments also address related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

*Date of issuance:* June 3, 2003.