

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 212 and 187.

*Facility Operating License Nos. NPF-14 and NPF-22:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 29, 2003. (68 FR 22752).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 3, 2003.

*No significant hazards consideration comments received:* No.

*PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania*

*Date of application for amendments:* October 31, 2002.

*Brief description of amendments:* These amendments revised Technical Specifications, Section 3.3.6.1, "Primary Containment Isolation Instrumentation," to add an ACTIONS Note allowing intermittent opening, under administrative control, of penetration flow paths that are isolated. Additionally, these amendments revised TSs Section 3.3.6.1 to breakout the traversing incore probe system isolation as a separate isolation Function with an associated Required Action to isolate the penetration within 24 hours rather than immediately initiating a unit shutdown.

*Date of issuance:* June 5, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 213 and 188.

*Facility Operating License Nos. NPF-14 and NPF-22:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 24, 2002 (67 FR 78523).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 5, 2003.

*No significant hazards consideration comments received:* No.

*Southern Nuclear Operating Company, Inc., et al., Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia*

*Date of application for amendments:* May 8, 2002, as supplemented by letters dated November 26, 2002, and April 10, 2003.

*Brief description of amendments:* The amendments revise the Reactor Core Safety Limits curve in Technical Specifications (TS) Figure 2.1.1-1, and the Over Temperature Delta Temperature (OTDT) and Over Power Delta Temperature (OPDT) reactor trip

functions described in TS Table 3.3.1-1. These changes will provide Vogtle Electric Generating Plant (VEGP), Units 1 and 2 with increased operating margins that will increase the OTDT and OPDT setpoints to account for hot leg temperature fluctuations that are part of the VEGP Setpoint Margin Recovery Program.

*Date of issuance:* June 4, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 128/106.

*Facility Operating License Nos. NPF-68 and NPF-81:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 23, 2002.

The supplements dated November 26, 2002, and April 10, 2003, provided clarifying information that did not change the scope of the May 8, 2002, application nor the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 4, 2003.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket No. 50-327, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendment:* October 4, 2002, as supplemented February 19, 2003, and May 19, 2003.

*Brief description of amendment:* The amendments revise Technical Specification (TS) 6.8.4.h, Containment Leakage Rate Testing Program, to allow the licensee to postpone its Appendix J, Type A, Containment Integrated Leak Rate Test (ILRT) for 5 years. Specifically, for Unit 1 the performance of the spring 2003 ILRT may be deferred up to 5 years but no later than spring 2008, and for Unit 2 performance of the fall 2003 ILRT may be deferred up to an additional 3.5 years but no later than spring 2007. In Amendment No. 265 to the Facility Operating License No. DPR-79 for SQN, Unit 2, TS 6.8.4.h was revised to allow the licensee to postpone the ILRT one cycle (i.e., 1.5 years) from spring 2002. Therefore, the total deferral for SQN, Unit 2 from the original requirement to perform a ILRT in spring 2002 will be up to 5 years.

*Date of issuance:* May 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days of issuance.

*Amendment Nos.:* 287 and 276.

*Facility Operating License No. DPR-77:* Amendment revises the technical specifications.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5681).

The February 19, and May 19, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the scope of the application.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 29, 2003.

*No significant hazards consideration comments received:* No.

*TXU Generation Company LP, Docket Nos. 50-445 and 50-446, Comanche Peak Steam Electric Station, Unit Nos. 1 and 2, Somervell County, Texas*

*Date of amendment request:*

November 19, 2002, as supplemented by letters dated February 5 and May 5, 2003.

*Brief description of amendments:* The amendments revise Appendix B to the Facility Operating License, Environmental Protection Plan (EPP), to replace references to the U.S. Environmental Protection Agency's National Pollutant Discharge Elimination System expired permit. The amendments also contain minor changes to the EPP to be consistent with the provisions of the current Texas Pollutant Discharge Elimination System permit and the Final Environmental Statement—Operating License Stage, and consolidate the Unit 1 and Unit 2 EPPs into a single document.

*Date of issuance:* May 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 104 and 104.

*Facility Operating License Nos. NPF-87 and NPF-89:* The amendments revised the Facility Operating License, Appendix B, "Environmental Protection Plan."

*Date of initial notice in Federal Register:* December 24, 2002 (67 FR 78524).

The supplemental letters provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated May 29, 2003.

*No significant hazards consideration comments received:* No.

*Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri*

*Date of application for amendment:* March 21, 2003.