

Resources Services, Inc., Millstone Power Station, Building 475, 5th Floor, Rope Ferry Road, Rt. 156, Waterford, Connecticut 06385.

NRC Section Chief: John A. Nakoski.

Notice of Issuance of Amendments to Facility Operating Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for A Hearing in connection with these actions was published in the **Federal Register** as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr@nrc.gov.

AmerGen Energy Company, LLC, Docket No. 50-461, Clinton Power Station, Unit 1, DeWitt County, Illinois

Date of application for amendment: November 16, 2001, as supplemented by letters dated October 4, 2002, and March 28, 2003.

Brief description of amendment: The amendment revises Technical Specification (TS) 3.6.2.2, "Suppression Pool Water Level," and TS 3.6.2.4, "Suppression Pool Makeup System," to permit draining the reactor cavity pool portion of the upper containment pool in MODE 3, "Hot Shutdown," with the reactor vessel pressure less than 235 psig.

Date of issuance: June 12, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 156.

Facility Operating License No. NPF-62: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: April 2, 2002 (67 FR 15621). The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** Notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 12, 2003.

No significant hazards consideration comments received: No.

Carolina Power & Light Company, Docket Nos. 50-325 and 50-324, Brunswick Steam Electric Plant, Units 1 and 2, Brunswick County, North Carolina

Date of amendment request: June 26, 2002, as supplemented November 22, 2002.

Brief description of amendment: The amendments change the Technical Specifications for the pressure-temperature limits curves in Technical Specification 3.4.9, "RCS Pressure and Temperature (P/T) Limits."

Date of issuance: June 18, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance

Amendment No.: 228 and 256.

Facility Operating License Nos. DPR-71 and DPR-62: Amendments revise the Technical Specifications.

Date of initial notice in Federal Register: August 6, 2002 (67 FR 50949). The November 22, 2002, supplement contained clarifying information only and did not change the initial no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 18, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-269, 50-270, and 50-287, Oconee Nuclear Station, Units 1, 2, and 3, Oconee County, South Carolina

Date of application of amendments: October 24, 2002, as supplemented by letters dated November 21, 2002, and February 19, 2003.

Brief description of amendments: The amendments revise TS 3.5.3, Low Pressure Injection, Condition A, to change the Completion Time from 72 hours to 7 days. This revision will allow longer corrective maintenance to be completed at power, without requiring a plant shutdown. It will also reduce shutdowns due to a Limiting Condition for Operation requirement.

Date of Issuance: June 18, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 332, 332, and 333.

Renewed Facility Operating License Nos. DPR-38, DPR-47, and DPR-55: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 24, 2002 (67 FR 78517).

The supplement dated November 21, 2002, did not change the scope of the October 24, 2002, application; however it did change the licensee's proposed No Significant Hazards Consideration Determination (NSHCD). The supplement dated February 19, 2003, provided clarifying information that did not change the scope of the October 24, 2002, application nor the initial proposed NSHCD.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 18, 2003.

No significant hazards consideration comments received: No.

Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana

Date of amendment request: March 19, 2003.

Brief description of amendment: The amendment deletes Technical Specification (TS) 5.5.3, "Post Accident Sampling," and thereby eliminates the requirements to have and maintain the post accident sampling system at River Bend Station, Unit 1. The amendment also addresses related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."