

*Date of issuance:* June 23, 2003.  
*Effective date:* As of the date of issuance and shall be implemented within 120 days from the date of issuance.

*Amendment No.:* 134.

*Facility Operating License No. NPF-47:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 29, 2003 (68 FR 22746).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 23, 2003.

No significant hazards consideration comments received: No.

**FirstEnergy Nuclear Operating Company, et al., Docket No. 50-412, Beaver Valley Power Station, Unit 2, Beaver County, Pennsylvania**

*Date of application for amendment:* July 24, 2002, as supplemented February 4, 2003.

*Brief description of amendment:* The amendment changed the MSIV full-closure stroke time of Technical Specification (TS) surveillance requirement 4.7.1.5 from 5 seconds to 6 seconds. Additionally, the once-per-92-day requirement to part-stroke exercise the main steam isolation valves (MSIVs) was replaced with criteria to test each MSIV pursuant to TS 4.0.5, which requires testing in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI.

*Date of issuance:* June 25, 2003.

*Effective date:* Effective the day of issuance to be implemented within 60 days.

*Amendment No.:* 137.

*Facility Operating License No. NPF-73:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* September 17, 2002 (67 FR 58644). The supplement dated February 4, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 25, 2003.

No significant hazards consideration comments received: No.

**Florida Power Corporation, et al., Docket No. 50-302, Crystal River Unit No. 3 Nuclear Generating Plant, Citrus County, Florida**

*Date of application for amendment:* July 3, 2002, as supplemented September 24, 2002, January 10, 2003, and March 20, 2003.

*Brief description of amendment:* The amendment revises Improved Technical Specification (ITS) 3.8.1 and associated Bases, "AC Sources-Operating," by extending the allowed outage time for the emergency diesel generators from 72 hours to 14 days.

*Date of issuance:* June 13, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance except for installation of an Aac source. An Aac source as described in the licensee's application supplement dated March 20, 2003, shall be installed before completion of refueling outage 14, as discussed in the NRC Safety Evaluation dated June 13, 2003. Implementation shall include incorporation of a description of the Aac source into the next scheduled Final Safety Analysis Report update after the Aac installation.

*Amendment No.:* 207.

*Facility Operating License No. DPR-72:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* August 6, 2002 (67 FR 50955). The September 24, 2002, January 10, 2003, and March 20, 2003, supplements contained clarifying information only, and did not change the initial no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 2003.

No significant hazards consideration comments received: No.

**Nuclear Management Company, LLC, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota**

*Date of application for amendment:* March 19, 2003.

*Brief description of amendment:* The amendment deletes Technical Specification 6.8.C, "Post Accident Sampling," and thereby eliminates the requirements to have and maintain the post accident sampling system at the Monticello Nuclear Generating Plant.

*Date of Issuance:* June 17, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment No.:* 136.

*Facility Operating License No. DPR-22:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* May 13, 2003 (68 FR 25655).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 17, 2003.

No significant hazards consideration comments received: No.

**PSEG Nuclear, LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey**

*Date of application for amendment:* February 14, 2003.

*Brief description of amendment:* The amendment revises Technical Specification (TS) 3/4.3.4.2 to extend the surveillance test intervals and allowed out-of-service times for the end-of-cycle recirculation pump trip system instrumentation. In addition, the TS Bases have been revised to address the proposed changes.

*Date of issuance:* June 24, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment No.:* 148.

*Facility Operating License No. NPF-57:* This amendment revises the TSs.

*Date of initial notice in Federal Register:* April 15, 2003 (68 FR 18284).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 24, 2003.

No significant hazards consideration comments received: No.

**PSEG Nuclear LLC, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey**

*Date of application for amendments:* September 26, 2002, as supplemented on March 20, 2003.

*Brief description of amendments:* The amendments revise setpoint and allowable values of the steam generator (SG) low-low level trip function in Technical Specification (TS) Table 2.2-1, "Reactor Trip System Instrumentation Trip Setpoints," and TS Table 3.3-4, "Engineered Safety Feature Actuation System Instrumentation Trip Setpoints." The TS changes are necessary to account for a flow-induced pressure drop through the mid-deck plate inside the SG in the SG water level measurement.

*Date of issuance:* June 13, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 30 days.

*Amendment Nos.:* 257 and 238.

*Facility Operating License Nos. DPR-70 and DPR-75:* The amendments revised the TSs.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5680).

The March 20, 2003, supplement contained clarifying information and did not change the staff's proposed finding of no significant hazards consideration.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 13, 2003.