

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket No. 50-364, Joseph M. Farley Nuclear Plant, Unit 2, Houston County, Alabama

Date of amendments request: March 31, 2003, as supplemented by letter dated April 29, 2003.

Brief description of amendments: The amendment modifies Technical Specifications (TS) Surveillance Requirement (SR) 3.4.11.1, for Farley, Unit 2 only by the addition of the following note that states, "Not required to be performed for Unit 2 for the remainder of operating cycle 16 for Q2B31MOV8000B." In addition, a temporary TS SR 3.4.11.4 is added to provide compensatory action for this block valve while SR 3.4.11.1 is suspended. Further, this SR requires that power to the Farley, Unit 2 Power Operated Relief Valve Q2B31MOV8000B be checked at least every 24 hours for the remainder of Operating Cycle 16.

Date of issuance: June 13, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 151.

Facility Operating License No. NPF-8: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: May 13, 2003 (68 FR 25658).

The supplement dated April 29, 2003, provided clarifying information that did not change the scope of the March 31, 2003, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 13, 2003.

No significant hazards consideration comments received: No.

STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas

Date of amendments request: February 14, 2002, as supplemented by letters dated July 29, 2002 and March 27, 2003.

Brief description of amendments: The amendments revise STP technical specifications to eliminate shutdown actions associated with radiation monitoring instrumentation. The proposed changes will enhance plant reliability by reducing exposure to unnecessary shutdowns and increase operational flexibility, and relax certain other restrictions.

Date of issuance: June 9, 2003.

Effective date: As of the date of issuance to be implemented within 4 months from the date of issuance.

Amendment Nos.: Unit 1—153; Unit 2—141.

Facility Operating License Nos. NPF-76 and NPF-80: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 2, 2002 (67 FR 15629).

The July 29, 2002, and March 27, 2003, supplemental letters provided clarifying information that was within the scope of the original **Federal Register** Notice (67 FR 15629) and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 9, 2003.

No significant hazards consideration comments received: No.

TXU Generation Company LP, Docket Nos. 50-445 and 50-446, Comanche Peak Steam Electric Station, Unit Nos. 1 and 2, Somervell County, Texas

Date of amendment request: December 4, 2002.

Brief description of amendments: The amendments revise several Limiting Conditions for Operation (LCO) Notes and Required Actions in the Technical Specifications that require suspension of operations involving positive reactivity additions or suspension of operations involving reactor coolant system boron concentration reductions. The amendments revise these LCO Notes and Required Actions to allow small, controlled, safe insertions of positive reactivity, but limit the introduction of positive reactivity such that compliance with the required shutdown margin or refueling boron concentration limits will still be satisfied.

Date of issuance: June 24, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment Nos.: 105 and 105.

Facility Operating License Nos. NPF-87 and NPF-89: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: January 7, 2003 (68 FR 813).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 24, 2003.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 30th day of June 2003.

For the Nuclear Regulatory Commission.

Ledyard B. Marsh,

Acting Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 03-17028 Filed 7-7-03; 8:45 am]

BILLING CODE 7590-01-P

OVERSEAS PRIVATE INVESTMENT CORPORATION

July 17, 2003, Board of Directors Meeting; Sunshine Act

TIME AND DATE: Thursday, July 17, 2003, 1:30 p.m. (Open Portion). 1:45 p.m. (Closed Portion).

PLACE: Offices of the Corporation, Twelfth Floor Board Room, 1100 New York Avenue, NW., Washington, DC.

STATUS: Meeting open to the public from 1:30 p.m. to 1:45 p.m. Closed portion will commence at 1:45 p.m. (approx.).

MATTERS TO BE CONSIDERED:

1. President's Report.
2. Testimonial D. Cameron Friday.
3. Approval of April 24, 2003 Minutes (Open Portion).

FURTHER MATTERS TO BE CONSIDERED: (Closed to the Public 1:45 p.m.)

1. Finance Project in Brazil
2. Finance Project in Russia
3. Insurance Project in Croatia
4. Approval of April 24, 2003 Minutes (Closed Portion)
5. Pending Major Projects
6. Reports

FOR FURTHER INFORMATION CONTACT:

Information on the meeting may be obtained from Connie M. Downs at (202) 336-8438.

Dated: July 3, 2003.

Connie M. Downs,

Corporate Secretary, Overseas Private Investment Corporation.

[FR Doc. 03-17344 Filed 7-3-03; 12:10 am]

BILLING CODE 3210-01-M

POSTAL SERVICE

Board of Governors; Sunshine Act Meeting

Board Votes to Close June 27, 2003, Meeting

By telephone vote on June 27, 2003, the Board of Governors of the United States Postal Service voted unanimously to close to public observation its meeting held in Washington, DC, via teleconference. The Board determined that prior public notice was not possible.

Items Considered

1. Personnel Matter.