

within 90 days from the date of issuance.

Amendment Nos.: 206 & 200.

Facility Operating License Nos. NPF-35 and NPF-52: Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* October 29, 2002 (67 FR 66008).

The supplement dated June 18, 2003, provided clarifying information that did not change the scope of the August 26, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 10, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: December 12, 2002, as supplemented by letters dated March 27 and April 23, 2003.

Brief description of amendments: The amendments revise the Technical Specifications (TS) regarding the reactor vessel pressure-temperature limit curves and revise the low-temperature overpressure protection limits. The licensee also requested that a change be made to TS Table 3.3.2-1, Footnote (c) to correct what was claimed to be an editorial error. This request was not supported by sufficient information and, accordingly, is denied.

Date of issuance: July 3, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment Nos.: 214 & 195.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* January 7, 2003 (68 FR 801).

The supplement dated March 27 and April 23, 2003, provided clarifying information that did not change the scope of the December 12, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 3, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: August 26, 2002, as supplemented by letter dated June 18, 2003.

Brief description of amendments: The amendments revise the Technical Specifications regarding the Diesel Fuel Oil Testing Program.

Date of issuance: July 10, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment Nos.: 215 & 195.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* October 29, 2002 (67 FR 66008).

The supplement dated August 26, 2002, provided clarifying information that did not change the scope of the June 18, 2003, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 10, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., System Energy Resources, Inc., South Mississippi Electric Power Association, and Entergy Mississippi, Inc., Docket No. 50-416, Grand Gulf Nuclear Station, Unit 1, Claiborne County, Mississippi

Date of application for amendment: March 19, 2003.

Brief description of amendment: The amendment deletes Technical Specification (TS) 5.5.3, "Post Accident Sampling," and License Condition 2(C)(33)(c) from Facility Operating License NPF-29, thereby eliminating the requirement to have and maintain the post-accident sampling system at Grand Gulf Nuclear Station, Unit 1. The amendment also addresses related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment."

Date of issuance: June 30, 2003.

Effective date: As of the date of issuance and shall be implemented within 120 days of issuance.

Amendment No: 158.

Facility Operating License No. NPF-29: The amendment revises the Technical Specifications and deletes License Condition 2(C)(33)(c).

*Date of initial notice in **Federal Register**:* May 13, 2003 (68 FR 25652).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 30, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: January 13, 2003, supplements dated February 27, March 6, March 14, April 30, June 9, and June 30, 2003.

Brief description of amendment: The proposed amendment would revise the Kewaunee Nuclear Power Plant Facility Operating License and Technical Specifications to increase the licensed rated power by 1.4 percent from 1650 megawatts thermal to 1673 megawatts thermal using measurement uncertainty recapture.

Date of issuance: July 8, 2003.

Effective date: As of the date of issuance and shall be implemented within 120 days.

Amendment No.: 168.

Facility Operating License No. DPR-43: Amendment revised the Facility Operating License and Technical Specifications.

*Date of initial notice in **Federal Register**:* February 4, 2003 (68 FR 5679).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 8, 2003.

No significant hazards consideration comments received: No.

PSEG Nuclear, LLC, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey

Date of application for amendments: January 29, 2003.

Brief description of amendments: The amendments revise Salem, Unit No. 1, Technical Specifications (TSs) Section 3/4.7.6, and Salem, Unit No. 2, TSs 3/4.2.2, 3/4.7.6, and Table 3.3-6. These changes are administrative and editorial in nature, and correct errors made during the implementation of previously-approved TS changes.

Date of issuance: June 26, 2003.

Effective date: As of the date of issuance, and shall be implemented within 60 days.

Amendment Nos.: 258 and 239.

Facility Operating License Nos. DPR-70 and DPR-75: The amendments revised the TSs.

*Date of initial notice in **Federal Register**:* April 15, 2003 (68 FR 18284).