

at the Commission's Public Document Room, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by e-mail to pdr@nrc.gov.

Arizona Public Service Company, et al., Docket Nos. STN 50-528, STN 50-529, and STN 50-530, Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, Maricopa County, Arizona.

Date of application for amendments: August 28, 2002.

Brief description of amendments: The amendments extend the expiration date of the operating licenses from December 31, 2024, to June 1, 2025, for Unit 1, December 9, 2025, to April 24, 2026, for Unit 2, and March 25, 2027, to November 25, 2027, for Unit 3 of Palo Verde Nuclear Generating Station.

Date of Issuance: July 15, 2003.

Effective date: July 15, 2003, and shall be implemented within 60 days of the date of issuance.

Amendment Nos.: Unit 1-147, Unit 2-147, Unit 3-147.

Facility Operating License Nos. NPF-41, NPF-51, and NPF-74: The amendments revised the Operating Licenses.

Date of initial notice in Federal Register: October 15, 2002 (67 FR 63688). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 15, 2003.

No significant hazards consideration comments received: No.

Calvert Cliffs Nuclear Power Plant, Inc., Docket Nos. 50-317 and 50-318, Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 (CCNPP), Calvert County, Maryland.

Date of application for amendments: June 11, 2002, as supplemented May 2, 2003, and June 23, 2003.

Brief description of amendments: These amendments revise the CCNPP Technical Specification Administrative Controls Section to incorporate six changes previously approved for the Improved Standard Technical Specifications and one administrative change in renumbering pages.

Date of issuance: July 16, 2003.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment Nos.: 259 and 236.

Renewed Facility Operating License Nos. DPR-53 and DPR-69: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: September 3, 2002 (67 FR 56318). The May 9, 2003, letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the initial proposed no significant hazards consideration determination as published in the **Federal Register** on September 3, 2002 (67 FR 56318). The June 23, 2003, letter withdrew the requested change dealing with clarifying references to 10 CFR part 20 in the Technical Specifications and did not change the initial proposed no significant hazards consideration determination as published in the **Federal Register** on September 3, 2002 (67 FR 56318). The Commission's related evaluation of these amendments is contained in a Safety Evaluation dated July 16, 2003.

No significant hazards consideration comments received: No.

Detroit Edison Company, Docket No. 50-341, Fermi 2, Monroe County, Michigan

Date of application for amendment: February 13, 2003.

Brief description of amendment: The amendment revises Technical Specification (TS) 5.5.10, "Technical Specifications (TS) Bases Control Program," to provide consistency with the changes to 10 CFR 50.59, which were published in the **Federal Register** (64 FR 53582) on October 4, 1999, and became effective March 13, 2001. Specifically, TS 5.5.10 has been revised to remove the phrase "unreviewed safety question."

Date of issuance: July 22, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 156.

Facility Operating License No. NPF-43: The amendment revises the Technical Specifications.

Date of initial notice in Federal Register: May 27, 2003 (68 FR 28848). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 22, 2003.

No significant hazards consideration comments received: No.

Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana

Date of amendment request: March 20, 2002, as supplemented by letter dated May 28, 2003.

Brief description of amendment: The amendment revises the reporting requirements specified in Section 2.E of the Facility Operating License and Technical Specification Section 5.6.4 by eliminating requirements that provide the U.S. Nuclear Regulatory Commission with information that is not risk significant, and change the reporting time period to be consistent with Section 50.73 of Title 10 of the Code of Federal Regulations.

Date of issuance: July 16, 2003.

Effective date: As of the date of issuance and shall be implemented 30 days from the date of issuance.

Amendment No.: 135.

Facility Operating License No. NPF-47: The amendment revised the Facility Operating License and Technical Specifications.

Date of initial notice in Federal Register: April 30, 2002 (67 FR 21286). The May 28, 2003, supplemental letter withdrew a portion of the original amendment request, but did not expand the scope of the original **Federal Register** notice or change the proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 16, 2003.

No significant hazards consideration comments received: No.

Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana

Date of amendment request: August 15, 2002, as supplemented by letter dated May 9, 2003.

Brief description of amendment: The amendment revises the reactor vessel surveillance program required by Title 10 of the Code of Federal Regulations, part 50, appendix H, section IIIB.3, allowing River Bend Station to incorporate the Boiling Water Reactor Vessel Internals Project Integrated Surveillance Program into the licensing basis.

Date of issuance: July 24, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 136.

Facility Operating License No. NPF-47: The amendment consists of NRC staff approval of changes to the Updated Safety Analysis Report.