

Date of issuance: July 02, 2003.

Effective date: Date of issuance to be implemented within [30] days from the date of issuance.

Amendment No.: 169.

Facility Operating License No. DPR-36: The amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* May 27, 2003 (68 FR 28854). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 02, 2003.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska

Date of amendment request: October 8, 2002.

Brief description of amendment: The amendment changes the title of Shift Supervisor to Shift Manager. This amendment also replaces plant-specific titles with generic titles consistent with Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler TSTF-65, Rev. 1.

Date of issuance: July 15, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 200.

Facility Operating License No. DPR-46: Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* May 27, 2003 (68 FR 28854). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 15, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket Nos. 50-282 and 50-306, Prairie Island Nuclear Generating Plant, Units 1 and 2, Goodhue County, Minnesota

Date of application for amendments: March 19, 2003.

Brief description of amendments: The amendments revise Technical Specification (TS) Section 5.3, "Plant Staff Qualifications." The amendments update requirements that have been outdated based on licensed operator training programs being accredited by the National Academy for Nuclear Training and promulgation of the revised Title 10 of the Code of Federal Regulations, part 55, "Operators' Licenses."

Date of issuance: July 22, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 159 and 150.

Facility Operating License Nos. DPR-42 and DPR-60: Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* April 15, 2003 (68 FR 18281). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 22, 2003.

No significant hazards consideration comments received: No.

Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California

Date of application for amendments: April 10, 2002.

Brief description of amendments: The license amendments revised several required actions in the Diablo Canyon Nuclear Power Plant (DCPP) Technical Specifications (TSs) that require suspension of operations involving positive reactivity additions or suspension of operations involving reactor coolant system (RCS) boron concentration reductions. In addition, the amendments revised several Limiting Condition for Operation notes that preclude reductions in RCS boron concentration when a reactor coolant pump(s) and/or a residual heat removal pump(s) are removed from operation. The changes allow small, controlled, safe insertions of positive reactivity, but limit the introduction of positive reactivity to ensure that compliance with the required shutdown margin or refueling boron concentration limits are satisfied.

Date of issuance: July 10, 2003.

Effective date: July 10, 2003, and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: Unit 1-158; Unit 2-159.

Facility Operating License Nos. DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* June 11, 2002 (67 FR 40024). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 10, 2003.

No significant hazards consideration comments received: No.

Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California

Date of application for amendments: February 28, 2003, as supplemented by letter dated June 26, 2003.

Brief description of amendments: The amendments revise Technical Specification (TS) Section 3.5.2,

"ECCS—Operating," Action A to allow a one-time increase in the allowed outage time for centrifugal charging pump (CCP) 1-1, for the purpose of seal replacement during Unit 1's Cycle 12 from 72 hours to 7 days. Additionally, the amendments delete a similar one-time TS change for Unit 2's CCP 2-1 that has expired.

Date of issuance: July 15, 2003.

Effective date: July 15, 2003, and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: Unit 1-159; Unit 2-160.

Facility Operating License Nos. DPR-80 and DPR-82: The amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* April 29, 2003 (68 FR 22753). The June 26, 2003, supplemental letter provided additional clarifying information that did not expand the scope of the application as originally noticed and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 15, 2003.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket No. 50-364, Joseph M. Farley Nuclear Plant, Unit 2, Houston County, Alabama

Date of amendments request: February 11, 2003.

Brief Description of amendment: The amendment modifies Technical Specifications (TS) to allow a 40-month inspection interval for Farley, Unit 2 after the completion of the first post-replacement in-service inspection, rather than the completion of two consecutive inspections resulting in a classification of C-1.

Date of issuance: July 14, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment No.: 153.

Facility Operating License No. NPF-8: Amendment revises the Technical Specifications.

*Date of initial notice in **Federal Register**:* May 13, 2003 (68 FR 25657). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 14, 2003.

No significant hazards consideration comments received: No.