

## COMPLIANCE REQUIREMENTS TABLE

Systems that are . . .	Must perform . . . <sup>a,b</sup>	And comply by . . .
(1) Subpart H systems serving $\geq 10,000$ people that currently provide filtration or that are unfiltered and required to install filtration.	(i) 24 months of source water monitoring for <i>Cryptosporidium</i> , <i>E. coli</i> and turbidity at least once each month beginning no later than [Date 6 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ]. (ii) Treatment technique implementation, if necessary.	Submitting a monthly report to EPA no later than ten days after the end of the first month following the month when the sample is taken.  Installing treatment and complying with the treatment technique no later than [Date 72 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ] <sup>c</sup> .
(2) Subpart H systems serving $\geq 10,000$ people that are unfiltered and meet the filtration avoidance criteria of § 141.71.	(i) 24 months of source water monitoring for <i>Cryptosporidium</i> at least once each month beginning no later than [Date 6 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ]. (ii) Treatment technique implementation, if necessary.	Submitting a monthly report to EPA no later than ten days after the end of the first month following the month when the sample is taken.  Installing treatment and complying with the treatment technique no later than [Date 72 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ] <sup>c</sup> .
(3) Subpart H systems serving $< 10,000$ people that currently provide filtration or that are unfiltered and required to install filtration and are not required to monitor for <i>Cryptosporidium</i> based on <i>E. coli</i> or other indicator monitoring results <sup>d</sup> .	12 months of source water monitoring for <i>E. coli</i> at least once every two weeks beginning no later than [Date 30 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ].	Submitting a monthly report to the State no later than ten days after the end of the first month following the month when the sample is taken.
(4) Subpart H systems serving $< 10,000$ people that currently provide filtration or that are unfiltered and required to install filtration and must perform <i>Cryptosporidium</i> monitoring based on <i>E. coli</i> or other indicator monitoring results <sup>d</sup> .	(i) 12 months of source water monitoring for <i>E. coli</i> at least once every two weeks beginning no later than [Date 30 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ] and 12 months of source water monitoring for <i>Cryptosporidium</i> at least twice each month beginning no later than [Date 48 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ]. (ii) Treatment technique implementation, if necessary.	Submitting a monthly report to the State no later than ten days after the end of the first month following the month when the sample is taken.  Installing treatment and complying with the treatment technique no later than [Date 102 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ] <sup>c</sup> .
(5) Subpart H systems serving $< 10,000$ people that are unfiltered and meet the filtration avoidance criteria of § 141.71.	(i) 12 months of source water monitoring for <i>Cryptosporidium</i> at least twice each month beginning no later than [Date 48 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ]. (ii) Treatment technique implementation, if necessary.	Submitting a monthly report to the State no later than ten days after the end of the first month following the month when the sample is taken.  Installing treatment and complying with the treatment technique no later than [Date 102 Months After Date of Publication of Final Rule in the <b>Federal Register</b> ] <sup>c</sup> .

<sup>a</sup> Any sampling performed more frequently than required must be evenly distributed over the sampling period.

<sup>b</sup> Systems may use data that meet the requirements in § 141.708 collected prior to the monitoring start date to substitute for an equivalent number of months at the end of the monitoring period.

<sup>c</sup> States may allow up to an additional two years for complying with the treatment technique requirement for systems making capital improvements.

<sup>d</sup> See § 141.702(b) to determine if *Cryptosporidium* monitoring is required.

(f) Systems that currently provide filtration or that are unfiltered and required to install filtration are not required to conduct source water monitoring under this subpart if the system currently provides or will provide a total of at least 5.5 log of treatment for *Cryptosporidium*, equivalent to meeting the treatment requirements of Bin 4 in § 141.720. Systems must notify the State not later than the date the system is otherwise required to submit a sampling schedule for monitoring under § 141.703 and must install and operate technologies to provide a total of at least 5.5 log of

treatment for *Cryptosporidium* by the applicable date in paragraph (e) of this section.

(g) Systems that are unfiltered and meet all the filtration avoidance criteria of § 141.71 are not required to conduct source water monitoring under this subpart if the system currently provides or will provide a total of at least 3 log *Cryptosporidium* inactivation, equivalent to meeting the treatment requirements for unfiltered systems with a mean *Cryptosporidium* concentration of greater than 0.01 oocysts/L in § 141.721. Systems must notify the State not later than the date

the system is otherwise required to submit a sampling schedule for monitoring under § 141.703. Systems must install and operate technologies to provide a total of at least 3 log *Cryptosporidium* inactivation by the applicable date in paragraph (e) of this section.

(h) Systems must comply with the uncovered finished water storage facility requirements in § 141.724 no later than [Date 36 Months After Date of Publication of Final Rule in the **Federal Register**].