

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by e-mail to pdr@nrc.gov.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 12, 2002, as supplemented on February 28, 2003.

Brief description of amendment: The amendment changes the surveillance requirements for the emergency diesel generators (EDGs) in Technical Specification (TS) 3/4.8.1.1, "Electrical Power Systems—A.C. Sources—Operating" and TS 3/4.8.1.2, "Electrical Power Systems—Shutdown." In addition, TS Section 6.0, "Administrative Controls," has been revised to add a new TS to define the program requirements for testing the EDG fuel oil.

Date of issuance: July 25, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 277.

Facility Operating License No. DPR-65: This amendment revised the TSs.

Date of initial notice in Federal Register: September 17, 2002 (67 FR 58639). The supplement dated February 28, 2003, provided additional information which clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 25, 2003.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 14, 2002, as supplemented on April 7, 2003.

Brief description of amendment: The amendment revises the Technical Specifications (TSs) related to Containment Systems. Specifically, the amendment: (1) Adds a new requirement for a Containment Tendon Surveillance Program to TS Section 6.0, "Administrative Controls;" (2) deletes TS 3/4.6.1.6, "Containment Structural Integrity;" (3) revises TS 3/4.6.1.1, "Containment Integrity," to add a new surveillance requirement that requires that containment structural integrity be verified in accordance with the Containment Tendon Surveillance Program; (4) revises TS 3/4.6.3.1, "Containment Isolation Valves," to add a new action statement that increases the allowed outage time from 4 hours to 72 hours for Containment Isolation Valves (CIVs) in closed systems; (5) makes other changes to the TSs for Containment Integrity and CIVs to provide clarity to the TSs; and (6) makes other administrative changes. In addition, the TS Bases have been revised to address the proposed changes.

Date of issuance: July 25, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 278.

Facility Operating License No. DPR-65: This amendment revised the TSs.

Date of initial notice in Federal Register: September 17, 2002 (67 FR 58640). The supplement dated April 7, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 25, 2003.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 12, 2002, as supplemented on October 21, 2002, and January 15, 2003.

Brief description of amendment: The amendment revises Technical

Specification (TS) 3.8.2.3, "Electrical Power Systems, D.C. Distribution—Operating;" TS 3.8.2.4, "Electrical Power Systems, D.C. Distribution—Shutdown;" and TS 3.8.2.5, "Electrical Power Systems, D.C. Distribution Systems (Turbine Battery)—Operating" to use standard TS terminology in order to provide enhanced readability and usability. The amendment also provides additional criteria for determining battery operability upon restoration from a recharge or equalizing charge.

Date of issuance: July 29, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 279.

Facility Operating License No. DPR-65: This amendment revises the TSs.

Date of initial notice in Federal Register: October 1, 2002 (67 FR 61677). The supplements dated October 21, 2002, and January 15, 2003, provided additional information which clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 29, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina

Date of application for amendments: November 20, 2002, as supplemented by letters dated January 21 and June 4, 2003.

Brief description of amendments: The amendments revised the Technical Specifications Required Actions requiring suspension of operations involving positive reactivity additions and various Notes that preclude reduction in boron concentration.

Date of issuance: July 29, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment Nos.: 207 & 201.

Facility Operating License Nos. NPF-35 and NPF-52: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 15, 2003, (68 FR 18273). The supplement dated June 4, 2003, provided clarifying information that did not change the scope of the November 20, 2002, application and its supplement dated January 21, 2003, nor