

the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 29, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket No. 50-370, McGuire Nuclear Station, Unit 2, Mecklenburg County, North Carolina

Date of application for amendments: January 31, as supplemented by letter dated May 1, 2003.

Brief description of amendments: The amendment authorizes a revision to the Updated Final Safety Analysis Report to allow the degassing and straightening of a bent Mark-BW irradiated fuel rod in the McGuire spent fuel pool.

Date of issuance: August 4, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment No.: 198.

Facility Operating License Nos. NPF-17: Amendment authorized revision of the Updated Final Safety Analysis Report.

Date of initial notice in Federal Register: April 15, 2003 (68 FR 18274). The supplement dated May 1, 2003, provided clarifying information that did not change the scope of the January 31, 2003, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 4, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: November 20, 2002, as supplemented by letters dated January 21 and June 4, 2003.

Brief description of amendments: The amendments revise the Technical Specifications Required Actions requiring suspension of operations involving positive reactivity additions and various Notes that preclude reduction in boron concentration.

Date of issuance: July 29, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment Nos.: 216 & 197.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 15, 2003 (68 FR 18273).

The supplement dated June 4, 2003, provided clarifying information that did not change the scope of the November 20, 2002, application and its supplement dated January 21, 2003, nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 29, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-286, Indian Point Nuclear Generating Unit No. 3, Westchester County, New York

Date of application for amendment: June 24, 2002, as supplemented on June 23, 2003.

Brief description of amendment: The amendment revises Technical Specification Surveillance Requirement (SR) 3.7.7.2 to require all city water header isolation valves be open rather than only the one header supply isolation valve. On June 23, 2003, the licensee withdrew its request for changes to SR 3.7.7.1 pertaining to the city water tank volume.

Date of issuance: August 4, 2003.

Effective date: As of the date of issuance, and shall be implemented within 30 days.

Amendment No.: 218.

Facility Operating License No. DPR-64: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 6, 2002 (67 FR 50952). The June 23, 2003, letter provided clarifying information that did not enlarge the scope of the original **Federal Register** notice or change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 4, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Date of application for amendment: January 31, 2003.

Brief description of amendment: The amendment revises the Technical Specification allowable values for two isolation condenser system isolation functions, namely the Steam Flow—High and Return Flow—High, for Units 2 and 3.

Date of issuance: July 30, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment No.: 200.

Facility Operating License No. DPR-19: The amendment revised the Technical Specifications.

Amendment No.: 192.

Facility Operating License No. DPR-25: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: April 15, 2003.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 30, 2003.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska

Date of amendment request: January 27, 2003.

Brief description of amendment: The amendment revised Technical Specifications (TS) 2.1.6, 3.2 (Table 3-5), and 5.9.1c as follows:

(1) TS 2.1.6(1), the "as-found" pressurizer safety valve (PSV) lift setting tolerance band of $\pm 1\%$ is increased to $+1\% - 3\%$ to allow for normal setpoint variance for Modes 1 and 2. The Basis of TS 2.1.6 is revised to clarify that the PSVs are still operable and capable of performing their safety function with the wider tolerance band. The other revisions to TS 2.1.6 are administrative in nature to change defined terms to upper case text.

(2) TS 3.2, Table 3-5, Item 3 is revised to require an "as-left" PSV lift setting tolerance band of $\pm 1\%$.

(3) TS 5.9.1c is revised to remove the requirement to provide a statement in the Monthly Operating Report (MOR) concerning failures or challenges to power operated relief valves or safety valves. Generic Letter 97-02, "Revised Contents of the Monthly Operating Report," does not require the MOR to provide this information.

Date of issuance: July 25, 2003.

Effective date: July 25, 2003, and shall be implemented within 30 days from the date of issuance.

Amendment No.: 129.

Facility Operating License No. DPR-40: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: March 18, 2003 (68 FR 12956).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 25, 2003.

No significant hazards consideration comments received: No.