

*Expedited Procedures* shall mean the process described in the Standard Small Generator Interconnection Procedures for (1) a Generating Facility no larger than 10 MW interconnecting with a Transmission Provider's Low-Voltage Transmission System, and (2) a Generating Facility failing the Super-Expedited Procedures. The Expedited Procedures use the Expedited Screening Criteria to determine whether the Small Generating Facility can be interconnected without any further Interconnection Studies.

*Expedited Screening Criteria* shall mean the technical variables that are employed in the Expedited Procedures for evaluating the impact of interconnecting the Small Generating Facility to the Transmission Provider's Transmission System as it exists at the time of the analysis.

*Fault Current* shall mean the current that is produced by an electrical fault, such as single-phase to ground, double-phase to ground, three-phase to ground, phase-to-phase, and three-phase. The Fault Current is several times larger in magnitude than the current that normally flows through a circuit. A protective device must be able to interrupt this Fault Current within a few cycles. The Fault Current increases when a new generator is interconnected.

*Federal Power Act* shall mean the Federal Power Act, as amended, 16 U.S.C. 791a *et seq.*

*FERC* shall mean the Federal Energy Regulatory Commission (Commission) or its successor.

*Force Majeure* shall mean any act of God, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party's control. A Force Majeure event does not include an act of negligence or intentional wrongdoing.

*Generating Facility* shall mean Interconnection Customer's device for the production of electricity identified in the Interconnection Request, but shall not include the Interconnection Customer's Interconnection Facilities.

*Generating Facility Capacity* shall mean the net capacity of the Generating Facility and the aggregate net capacity of the Generating Facility where it includes multiple energy production devices.

*Good Utility Practice* shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

*Governmental Authority* shall mean any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Transmission Provider, or any Affiliate thereof.

*Hazardous Substances* shall mean any chemicals, materials or substances defined as or included in the definition of "hazardous substances," "hazardous wastes," "hazardous materials," "hazardous constituents," "restricted hazardous materials," "extremely hazardous substances," "toxic substances," "radioactive substances," "contaminants," "pollutants," "toxic pollutants" or words of similar meaning and regulatory effect under any applicable Environmental Law, or any other chemical, material or substance, exposure to which is prohibited, limited or regulated by any applicable Environmental Law.

*High-Voltage* shall mean voltage levels at or above 69 kV.

*IEEE* shall mean the Institute of Electrical and Electronics Engineers.

*Initial Review* shall mean the Transmission Provider's review of the Interconnection Customer's Interconnection Request using the Super-Expedited Screening Criteria described in Section 3 of the Standard Small Generator Interconnection Procedures.

*In-Service Date* shall mean the date upon which the Interconnection Customer reasonably expects it will be ready to begin use of the Transmission Provider's Interconnection Facilities to obtain back feed power.

*Interconnection Customer* shall mean any entity, including the Transmission Provider, Transmission Owner or any of the Affiliates or subsidiaries of either, that proposes to interconnect its Generating Facility with the Transmission Provider's Transmission System.

*Interconnection Customer's Interconnection Facilities* shall mean all facilities and equipment, as identified in Appendix 2 of the Standard Small Generator Interconnection Agreement, that are located between the Generating Facility and the Point of Change of Ownership, including any modification, addition, or upgrades to such facilities and equipment necessary to physically and electrically interconnect the Generating Facility to the Transmission Provider's Transmission System. Interconnection Customer's Interconnection Facilities are sole use facilities.

*Interconnection Facilities* shall mean the Transmission Provider's Interconnection Facilities and the Interconnection Customer's Interconnection Facilities. Collectively, Interconnection Facilities include all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions or upgrades that are necessary to

physically and electrically interconnect the Generating Facility to the Transmission Provider's Transmission System. Interconnection Facilities are sole use facilities and shall not include Distribution Upgrades or Network Upgrades.

*Interconnection Facilities Study* shall mean a study conducted by the Transmission Provider or a third party consultant for the Interconnection Customer to determine a list of facilities (including Transmission Provider's Interconnection Facilities and Network Upgrades as identified in the Interconnection System Impact Study), the cost of those facilities, and the time required to interconnect the Generating Facility with the Transmission Provider's Transmission System. The scope of the study is defined the Standard Small Generator Interconnection Procedures.

*Interconnection Facilities Study Agreement* shall mean the form of agreement contained in Appendix 5 of the Standard Small Generator Interconnection Procedures for conducting the Interconnection Facilities Study.

*Interconnection Feasibility Study* shall mean a preliminary evaluation of the system impact and cost of interconnecting the Generating Facility to the Transmission Provider's Transmission System, the scope of which is described in the Standard Small Generator Interconnection Procedures.

*Interconnection Feasibility Study Agreement* shall mean the form of agreement contained in Appendix 3 of the Standard Small Generator Interconnection Procedures for conducting the Interconnection Feasibility Study.

*Interconnection Request* shall mean an Interconnection Customer's request, in the form of Appendix 6 to the Standard Small Generator Interconnection Procedures, in accordance with the Tariff, to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with the Transmission Provider's Transmission System.

*Interconnection Service* shall mean the service provided by the Transmission Provider associated with interconnecting the Interconnection Customer's Generating Facility to the Transmission Provider's Transmission System and enabling it to receive electric energy and capacity from the Generating Facility at the Point of Interconnection, pursuant to the terms of the Standard Small Generator Interconnection Agreement and, if applicable, the Transmission Provider's Tariff.

*Interconnection Study* shall mean any of the following studies: the Interconnection Feasibility Study, the Interconnection System Impact Study, and the Interconnection Facilities Study described in the Standard Small Generator Interconnection Procedures.

*Interconnection System Impact Study* shall mean an engineering study that evaluates the impact of the proposed interconnection on the safety and reliability of Transmission Provider's Transmission System and, if applicable, an Affected System. The study shall identify and detail the system impacts that would result if the Generating Facility