

## BPT LIMITATIONS

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
<b>Conventional Parameters</b>		
BOD <sub>5</sub> .....	163	53.0
* * * * *		
<sup>1</sup> mg/L (ppm).		
* * * * *		
ii. Removing the entry for "Selenium" in the BPT Limitations table under the heading "Metal Parameters."	i. Barium. ii. Titanium.	<b>§ 437.42 Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).</b> * * * * *
h. Paragraph (e) is amended by removing the following entries in the BPT Limitations table under the heading "Metal Parameters":	i. Paragraph (e) is amended by revising the entry for "Antimony" in the BPT Limitations table under the heading "Metal Parameters" to read as follows:	

## BPT LIMITATIONS

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
* * * * *		
<b>Metal Parameters</b>		
Antimony .....	0.928	0.679
* * * * *		
<sup>1</sup> mg/L (ppm).		
* * * * *		
<b>§ 437.44 [Amended]</b> 12. Section 437.44 is amended as follows: a. In paragraph (b)(1) by removing the following entries in the BAT Limitations table, under the heading "Metal Parameters": i. Barium. ii. Selenium. b. In paragraph (c)(1) by removing the following entries in the BAT Limitations table, under the heading "Metal Parameters": i. Barium. ii. Molybdenum. iii. Selenium. c. In paragraph (d)(1) by removing the entry for "Selenium" in the BAT	Limitations table under the heading "Metal Parameters." d. In paragraph (e) by removing the following entries in the BAT Limitations table under the heading "Metal Parameters": i. Barium. ii. Titanium. <b>§ 437.45 [Amended]</b> 13. Section 437.45 is amended as follows: a. In paragraph (b)(1) by removing the entry for "Barium" in the Performance Standards table, under the heading "Metal Parameters." b. In paragraph (c)(1) by removing the following entries in the Performance Standards table, under the heading "Metal Parameters":	i. Barium. ii. Molybdenum. c. In paragraph (e) by removing the following entries in the Performance Standards table under the heading "Metal Parameters": i. Barium. ii. Titanium. d. In paragraph (e) by revising the entry for "Antimony" in the Performance Standards table under the heading "Metal Parameters" to read as follows: <b>§ 437.45 New Source Performance Standards.</b> * * * * * (e) * * *

## PERFORMANCE STANDARDS

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
* * * * *		
<b>Metal Parameters</b>		
* * * * *		
Antimony .....	0.928	0.679