

§ 192.753 Caulked bell and spigot joints.

(a) Each cast iron caulked bell and spigot joint that is subject to pressures of more than 25 psi (172kPa) gage must be sealed with:

* * * * *

(b) Each cast iron caulked bell and spigot joint that is subject to pressures of 25 psi (172kPa) gage or less and is exposed for any reason must be sealed by a means other than caulking.

Issued in Washington, DC, on September 3, 2003.

Samuel G. Bonasso,

Acting Administrator.

[FR Doc. 03-23179 Filed 9-12-03; 8:45 am]

BILLING CODE 4910-60-P