

dated June 30, July 30, August 8, and 18, 2003.

Brief description of amendment: The amendment updates the existing reactor coolant system pressure and temperature limit curves (TS Figure 3.4.9-1) and extends their applicability to 32 effective full power years.

Date of issuance: August 25, 2003.

Effective date: As of the date of issuance and shall be implemented by September 1, 2003.

Amendment No.: 253.

Facility Operating License No. DPR-49: The amendment revised the Technical Specifications.

Date of initial notice in *Federal Register*: May 27, 2003 (68 FR 28855).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 25, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-263, Monticello Nuclear Generating Plant, Wright County, Minnesota

Date of application for amendment: January 29, 2003.

Brief description of amendment: The amendment revises the drywell leakage and sump monitoring detection section of the current Technical Specifications (TSs). Specifically, the changes clarify the associated definitions and divide TS 3.6.D/4.6.D, "Coolant Leakage," into two subsections and retitle it "Reactor Coolant System (RCS)." One of the subsections contains the Limiting Condition for Operations (LCOs) for RCS operational leakage, and the other subsection contains the LCOs for the RCS leakage detection instrumentation.

Date of issuance: August 21, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 137.

Facility Operating License No. DPR-22: Amendment revised the Technical Specifications.

Date of initial notice in *Federal Register*: April 15, 2003 (68 FR 18279).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 21, 2003.

No significant hazards consideration comments received: No.

Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2, San Luis Obispo County, California

Date of application for amendments: August 27, 2002, and its supplements dated May 15, June 26, and August 1, 2003.

Brief description of amendments: The amendments revised Table 3.3.1-1, "Reactor Trip System Instrumentation" of the technical specifications to replace the term "minimum measured flow per loop" to "measured loop flow" in the allowable value and nominal trip setpoint for the reactor coolant flow-low reactor trip function, and delete footnote (l). The amendments also allow an alternate method for the measurement of reactor coolant system (RCS) total volumetric flow rate through measurement of the elbow tap differential pressure on the RCS primary cold legs.

Date of issuance: August 21, 2003.

Effective date: August 21, 2003, and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: Unit 1-161; Unit 2-162.

Facility Operating License Nos. DPR-80 and DPR-82: The amendments revised the Technical Specifications.

Date of initial notice in *Federal Register*: January 7, 2003 (68 FR 810).

The May 15, June 26, and August 1, 2003, supplemental letters provided additional clarifying information, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 21, 2003.

No significant hazards consideration comments received: No.

Rochester Gas and Electric Corporation, Docket No. 50-244, R.E. Ginna Nuclear Power Plant, Wayne County, New York

Date of application for amendment: May 3, 2001, as supplemented August 7, 2001, October 29, 2001, May 3, 2002, October 7, 2002, November 5, 2002, and June 6, 2003.

Brief description of amendment: The amendment revised the Ginna Station Improved Technical Specifications to reflect design changes to the actuation circuitry associated with the Control Room Emergency Air Treatment System (CREATS). The proposed design changes consist of replacing the current diverse radiation monitors with two

Geiger-Mueller (GM) tubes powered from two separate safety-related power supplies which are configured into two redundant actuation logic trains using safety-grade digital instrumentation. The design changes are intended to increase system reliability by providing redundancy and reducing spurious actuations. The amendment changes limiting condition for operation 3.3.6 for the CREATS Actuation Instrumentation as follows:

a. Adds a new Condition to require immediately placing the CREATS in the emergency mode of operation upon the loss of two instrument channels/trains.

b. Adds a new surveillance requirement involving a CHANNEL CHECK of the Control Room Radiation Intake Monitors.

c. Revises Table 3.3.6-1 to increase the number of trains of Manual and Automatic Initiation Circuits from one train to two trains.

d. Extends the Completion Time of the Required Action for a loss of one channel/train from 1 hour to 7 days as the result of installing redundant channels/trains.

e. Revises Table 3.3.6-1 to remove reference to the iodine, noble gas, and particulate control room radiation intake monitors. These monitors will be replaced by the two new GM tubes.

f. Revises Table 3.3.6-1 to replace the column heading "Trip Setpoint" with "Allowable Value."

Date of issuance: August 29, 2003.

Effective date: August 29, 2003.

Amendment No.: 83.

Facility Operating License No. DPR-18: Amendment revised the Technical Specifications.

Date of initial notice in *Federal Register*: September 5, 2001 (66 FR 46481).

The supplemental letters referenced above provided clarifying information that did not change the scope of the amendment as described in the original notice, and did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 29, 2003.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-348 and 50-364, Joseph M. Farley Nuclear Plant, Units 1 and 2, Houston County, Alabama

Date of amendments request: September 24, 2002, as supplemented by letters dated May 20 and July 16, 2003.

Brief Description of amendments: The changes revise Technical Specifications