

(TS) 3.7.10, "Control Room Emergency Filtration/Pressurization System (CREFS)," and TS 3.7.12 "Penetration Room Filtration (PRF) System," to establish actions to be taken for inoperable ventilation systems due to a degraded control room pressure boundary or PRF and spent fuel pool room boundary, respectively. This revision approves changes that would allow up to 24 hours to restore the pressure boundary to an operable status when two ventilation trains are inoperable due to an inoperable pressure boundary in MODES 1, 2, 3, and 4. In addition, a Limiting Condition for Operation Note would be added to allow the pressure boundary to be opened intermittently under administrative control without affecting CREFS or PRF System operability. The applicable TS Bases have been revised to document the TS changes and to provide supporting information. These changes are based on Technical Specifications Task Force document TSTF-287, Revision 5.

*Date of issuance:* August 22, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 161 and 154.

*Facility Operating License Nos. NPF-2 and NPF-8:* Amendments revise the Technical Specifications.

*Date of initial notice in Federal Register:* November 12, 2002 (67 FR 68744).

The supplements dated May 20 and July 16, 2003, provided clarifying information that did not change the scope of the September 24, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 22, 2003.

*No significant hazards consideration comments received:* No.

*STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendment request:* May 14, 2003.

*Brief description of amendments:* The amendments revise Surveillance.

Requirement 4.6.2.1 for demonstrating operability of containment spray system spray nozzles to require verification of operability only after spray ring header maintenance that could result in nozzle obstructions without specifying the method of verification.

*Date of issuance:* August 20, 2003.

*Effective date:* As of the date of issuance and shall be implemented 30 days from the date of issuance.

*Amendment Nos.:* Unit 1-156; Unit 2-144.

*Facility Operating License Nos. NPF-76 and NPF-80:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* June 24, 2003 (68 FR 37582).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 20, 2003.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket Nos. 50-259, 50-260, and 50-296, Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama*

*Date of application for amendments:* April 15, 2003.

*Description of amendment request:* The amendments revised Technical Specification (TS) 3.7.3, "Control Room Emergency Ventilation (CREV) System," to allow up to 24 hours to restore the control room pressure boundary (CRPB) to operable status when two trains of the ventilation system are inoperable due to an inoperable CRPB in MODES 1, 2, and 3. In addition, a note is included to allow the pressure boundary to be opened intermittently under administrative controls without affecting the CREV System operability. The licensee revised the applicable TS Bases to make them consistent with the TS changes. These changes are based on TS Task Force Traveler No. 287, which was approved by the NRC on March 16, 2000.

*Date of issuance:* August 29, 2003.

*Effective date:* Date of issuance, to be implemented within 60 days.

*Amendment Nos.:* 246, 283 and 241.

*Facility Operating License Nos. DPR-33, DPR-52, and DPR-68:* Amendments revised the TSs.

*Date of initial notice in Federal Register:* May 27, 2003 (68 FR 28858).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated August 29, 2003.

*No significant hazards consideration comments received:* No.

*TXU Generation Company LP, Docket Nos. 50-445 and 50-446, Comanche Peak Steam Electric Station, Unit Nos. 1 and 2, Somervell County, Texas*

*Date of amendment request:* June 5, 2003.

*Brief description of amendments:* The amendments extend from 1 hour to 24 hours the completion time for Condition B of Technical Specification 3.5.1,

which defines requirements for the restoration of an emergency core cooling system accumulator when it has been declared inoperable for a reason other than boron concentration.

*Date of issuance:* August 25, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 106 and 106.

*Facility Operating License Nos. NPF-87 and NPF-89:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* July 8, 2003 (68 FR 40721).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 25, 2003.

*No significant hazards consideration comments received:* No.

*Virginia Electric and Power Company, et al., Docket Nos. 50-280 and 50-281, Surry Power Station, Units 1 and 2, Surry County, Virginia*

*Date of application for amendments:* June 9, 2003, as supplemented on July 28, 2003.

*Brief Description of amendments:* These amendments revise Section 6 of the Surry Power Station Technical Specifications (TS) for Units 1 and 2 to adopt the format for topical report references that are described in Industry/Technical Specifications Task Force Traveler, TSTF-363, Rev 0, "Revised Topical Report References in Improved Technical Specification (ITS) 5.6.5, [Core Operating Limits Report] COLR."

*Date of issuance:* August 27, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 30 days.

*Amendment Nos.:* 235 and 234.

*Renewed Facility Operating License Nos. DPR-32 and DPR-37:* Amendments change the Technical Specifications.

*Date of initial notice in Federal Register:* July 8, 2003 (68 FR 40722).

The July 28, 2003, supplement contained clarifying information only and did not change the initial proposed no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 27, 2003.

*No significant hazards consideration comments received:* No.

Dated at Rockville, Maryland, this 5th day of September 2003.