

Date of application for amendment: May 14, 2003, as supplemented by letters dated June 16, August 2, August 7, and August 20, 2003.

Brief description of amendment: This amendment revised the Technical Specifications to allow a one time exception, only during the Restart Test Plan, to allow entry into Mode 3 of operation without the high-pressure injection pumps being able of taking suction from the low-pressure injection trains when aligned for containment sump recirculation. The exception cannot be used for entry into Mode 2 or Mode 1.

Date of issuance: September 5, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment No.: 257.

Facility Operating License No. NPF-3: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: June 10, 2003 (68 FR 34668).

The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 5, 2003.

No significant hazards consideration comments received: No.

Florida Power Corporation, et al., Docket No. 50-302, Crystal River Unit No. 3 Nuclear Generating Plant, Citrus County, Florida.

Date of application for amendment: February 17, 2003.

Brief description of amendment: The amendment revises Technical Specification (ITS) 3.6.3 "Containment Isolation Valves," to allow verification by administrative means of isolation devices in high radiation areas, and isolation devices that are locked, sealed or otherwise secured.

Date of issuance: September 8, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days of issuance.

Amendment No.: 209.

Facility Operating License No. DPR-72: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: April 15, 2003 (68 FR 18277).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 8, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire.

Date of amendment request: October 11, 2002, as supplemented by letter dated May 29, 2003.

Description of amendment request: The amendment revises Technical Specification (TS) 3.4.9.1, "Reactor Coolant System [RCS]—Pressure/Temperature Limits," and TS 3.4.9.3, "Reactor Coolant System—Overpressure Protection Systems" and their associated Bases sections. Specifically, the changes replace TS Figures 3.4-2 "Reactor Coolant System Heatup Limitations," 3.4-3 "Reactor Coolant System Cooldown Limitations," and 3.4-4 "RCS Cold Overpressure Protection" to allow operation to 20 Effective Full Power Years.

Date of issuance: September 11, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 89.

Facility Operating License No. NPF-86: Amendment revises the TS.

Date of initial notice in Federal Register: December 10, 2002 (67 FR 75879). The May 29, 2003, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination nor expand the amendment beyond the scope of the initial notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 11, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire.

Date of amendment request: April 24, 2002.

Description of amendment request: The amendment revises surveillance requirements (SRs) in Technical Specification (TS) 4.6.2.1, "Containment Spray System," and TS 4.7.1.2.1b, "Auxiliary Feedwater System," and associated Bases Section 3/4.7.1.2. Specifically, the proposed changes would move SR acceptance criteria for containment spray and auxiliary feedwater pumps from the TSs to the Seabrook Station Technical Requirements Manual.

Date of issuance: September 12, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 90.

Facility Operating License No. NPF-86: The amendment revises the TSs.

Date of initial notice in Federal Register: June 11, 2002 (67 FR 40024).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 12, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: September 12, 2002, as supplemented March 27 and May 30, 2003.

Brief description of amendments: The amendments add surveillance requirements for Technical Specification (TS) 3.5.2, "ECCS—Operating," and TS 3.5.3, "ECCS—Shutdown," to verify, every 31 days, that the emergency core cooling system piping is full of water.

Date of issuance: September 5, 2003.

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment Nos.: 209 and 214.

Facility Operating License Nos. DPR-24 and DPR-27: Amendments revised the TSs.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5679).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 5, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket Nos. 50-259, 50-260, and 50-296, Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama.

Date of application for amendments: February 13, 2003, as supplemented April 14, 2003.

Description of amendment request: The amendments revised Technical Specification (TS) 4.2.1 "Fuel assemblies," to modify the fuel design description to encompass Framatome Advanced Nuclear Power fuel assemblies, and also to modify TS 4.3 "Fuel Storage," to remove nomenclature specific to Global Nuclear Fuels analysis methods.

Date of issuance: September 5, 2003.

Effective date: September 5, 2003.

Amendment Nos.: 247, 284, 242.

Facility Operating License Nos. DPR-33, DPR-52, and DPR-68: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: April 1, 2003 (68 FR 15763). The April 14, 2003, letter provided clarifying information that did not